

Addendum/Addenda

No./N° 2

Project Description / Description de projet M55 high voltage transformer		
Solicitation No./ N° de sollicitation 15-22099	Project No./N° de projet 5104	W.O. No./N° d'ordre de travail A1-006942-07-01
Departmental Representative / Représentant Ministériel Maurice Richard	Date Oct 16, 2015	
Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.		Nota: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.

1. Transformer secondary connection should be bus type, coordinate with existing bus way to 600V switchboard.
2. Power systems transformer is accepted as alternative.
3. Temporarily remove (3) existing door frames, and (3) existing lights to allow transformer transportation, reinstae to its original state after completion.
4. Provide mechanical protection to cover existing carpet during transformer transportation.

