

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des  
soumissions/Travaux publics et Services  
gouvernementaux Canada  
The Cambridge Building  
3 Queen Street/3, rue Queen  
Charlottetown  
Prince Edward Island  
C1A 4A2

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
The Cambridge Building  
3 Queen Street/3 rue, Queen  
PO Box 1268/CP 1268  
Charlottetown  
Prince Ed  
C1A 4A2

<b>Title - Sujet</b> Greenhouse Expansion, Harrington PE	
<b>Solicitation No. - N° de l'invitation</b> ED001-161244/A	<b>Amendment No. - N° modif.</b> 006
<b>Client Reference No. - N° de référence du client</b> R.077468.001	<b>Date</b> 2015-10-20
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWC-021-3706	
<b>File No. - N° de dossier</b> PWC-5-38082 (021)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-10-23</b>	<b>Time Zone</b> Fuseau horaire Atlantic Daylight Saving Time ADT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Donovan, Janine E.	<b>Buyer Id - Id de l'acheteur</b> pwc021
<b>Telephone No. - N° de téléphone</b> (506) 636-5347 ( )	<b>FAX No. - N° de FAX</b> (506) 636-4376
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This Solicitation Amendment No. Six (6) is raised to include the following Addendum No. Six (6).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

**All other terms and conditions remain the same.**

Addendum No. 6

### **QUESTIONS AND ANSWERS**

- Q1:** We will need to know if the wall of Building-80 that the addition is attached to is a fire-rated wall? Also, we need to know if the existing exterior door is a dedicated fire exit.
- R1:** The existing exterior wall on Grid 1, to which the addition is to be attached, is not fire-rated. Please note, no walls in the 'new' addition are required to be fire-rated or have a fire resistance rating. The existing double doors on Grid 1 is currently a required exit but has no required fire rating. The existing exit devices on these doors have no exterior trim so they function as an exit only with no "entry" capability since there is no way to retract the latch on the exterior side. When these door panels & associated exit devices are relocated to the new frame on Grid 1 they likewise will only function as the required exit and will continue to have no "entry" capability. While, the new doors to be installed on Grid 1, and their associated hardware, will allow egress through the doorway in either direction.
- Q2:** If yes, then the corridor through the addition would need to be rated as well. The travel distance would also need to be re-calculated.
- A2:** See responses for 1 above and 3 below.
- Q3:** Please provide information regarding Building-80 for fire exists and travel distances.
- R3:** Although, the new addition extends the original egress route at the North end of the building by approximately 12 meters, locations of exits will remain in compliance with NBCC-2010 requirements. NBCC-2010 Item 3.4.2.5(f) requires that travel distances to at least one exit do not exceed 30 m. With the addition, all floor areas are within 30 m of an exit.
- Q4:** Please provide sizes of the existing doors in Building 80 that are to be re-located. We need to know to allow the correct frame size in the new addition.

- 
- A4:** This will be part of the Design process. Please note, drawings of Building 80 will be made available to the successful proponent.
- Q5:** Also, is G40 Galvanneal coating acceptable for the new doors and frames?
- R5:** Products and materials will be considered as part of the Design process.
- Q6:** Also, The tender form indicates a completion date of March 28, 2015 and the milestone dates on page 10 of the Design-Build Terms of Reference indicate Substantial Completion of February 20, 2016. Would a Substantial Completion date of March 28, 2015 be acceptable? Also, can some exterior activities be completed after the March 20<sup>th</sup> date, asphalt for example, that are weather dependent?
- A6:** Substantial completion is to be March 28, 2015. The Milestone dates (page 10 of 43) within the Terms will be adjusted upon award. Seasonal deficiencies may be required at the time of Substantial.