

WHARF LIGHTING CONTROL/WIRING DIAGRAM

SCALE : N.T.S.

1 E6

NOTES:

1. CONTACTS RATED FOR 20 AMP, 120V
2. 20 AMP COIL



CONTACTOR WIRING DIAGRAM

SCALE : N.T.S.

2 E6



POWER CENTRE #1 – WIRING DIAGRAM

SCALE : N.T.S.



POWER CENTRE #2 – WIRING DIAGRAM

SCALE : N.T.S.



POWER CENTRE #3 – WIRING DIAGRAM

SCALE : N.T.S.

NOTE:

SPLICES IN ALL POWER CENTRE JUNCTION BOXES ARE TO BE MADE USING MECHANICAL BOLTED CONNECTORS AND HEAT SHRINK BOOTS.



POWER CENTRE #4 – WIRING DIAGRAM

SCALE : N.T.S.

NOTE:

SPLICES IN ALL POWER CENTRE JUNCTION BOXES ARE TO BE MADE USING MECHANICAL BOLTED CONNECTORS AND HEAT SHRINK BOOTS.



POWER CENTRE #5 – WIRING DIAGRAM

SCALE : N.T.S.

NOTE:

SPLICES IN ALL POWER CENTRE JUNCTION BOXES ARE TO BE MADE USING MECHANICAL BOLTED CONNECTORS AND HEAT SHRINK BOOTS.



POWER CENTRE #6 – WIRING DIAGRAM

SCALE : N.T.S.

NOTE:

SPLICES IN ALL POWER CENTRE JUNCTION BOXES ARE TO BE MADE USING MECHANICAL BOLTED CONNECTORS AND HEAT SHRINK BOOTS.



POWER CENTRE #7 – WIRING DIAGRAM

SCALE : N.T.S.

NOTE:

SPLICES IN ALL POWER CENTRE JUNCTION BOXES ARE TO BE MADE USING MECHANICAL BOLTED CONNECTORS AND HEAT SHRINK BOOTS.

Public Works and Government Services Canada / Travaux Publics et Services gouvernementaux Canada

revisions		date
0	ISSUED FOR TENDER	SEPT 2015

project / projet

ELECTRICAL SYSTEM INSTALLATION

WALLACE, CUMBERLAND CO.
NOVA SCOTIA

drawing / dessin

WIRING AND CONTROL DIAGRAMS & SCHEMATICS

designed G. BOWSER / conçu
date SEPT 2015
drawn K. WOLFE / dessiné
date SEPT 2015
approved / approuvé
date 2015 09

Tender / Soumission

PWGSC Project Manager Administered by project TPSGC

project number / no. du projet
R.076178.001

drawing no. / no. du dessin
E6

PWGSC B1 (2004)

E-DRM/GDD-E: 496702