



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency  
National Contracting Service  
Bid Receiving Unit  
111 Water St. East  
Cornwall ON K6H 6S3**

**Bid Fax: (877) 558-2349**

**AMENDMENT No.1**

INVITATION TO TENDER

APPEL D'OFFRES

**Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission à: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaires

Issuing Office - Bureau de distribution

Parks Canada Agency  
111 Water St.  
Cornwall, ON K6H 6S3

<b>Title - Sujet</b>	
<b>PEI National Park - Green Gables Replacement of Heat Pumps</b>	
<b>Solicitation No. - No. de l'invitation</b> 5P300-15-5432	<b>Date</b> 2015 - 10 - 20
<b>GETS Reference No. - No de reference de SEAG</b> PW-15-00702500	
<b>Client Reference No. - No. de référence du client</b>	
<b>Solicitation Closes</b> <b>L'invitation prend fin -</b>	<b>Time Zone</b> <b>Fuseau horaire -</b>
<b>at - à 02:00 PM</b> <b>on - le 2015-10-30</b>	<b>Heure Avancée de l'Est (HNE) / Eastern Daylight Saving Time (EDT)</b>
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b>	
Michel Marleau michel.marleau@pc.gc.ca	
<b>Telephone No. - No de téléphone</b>	<b>Fax No. - No de FAX:</b>
(613) 938-5822	(866) 246-6893
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b>	
See Herein	

**TO BE COMPLETED BY THE BIDDER  
À ÊTRE COMPLÉTÉ PAR LE  
SOUMISSIONNAIRE**

<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur :</b>	
<b>Telephone No. - No de téléphone:</b> <b>Facsimile No. - N° de télécopieur:</b>	
<b>Name and title of person authorized to sign on behalf of the Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
_____	_____
<b>Name</b>	<b>Title</b>
_____	_____
<b>Signature</b>	<b>Date</b>

# **AMENDMENT No.1**

## **THE PURPOSE OF THIS AMENDMENT IS TO GIVE EFFECT TO THE FOLLOWING CHANGE;**

1- The Specifications are to be modified as followed:

### **Specifications**

1. Summary of Work, Section 01 11 00:
  - a. Add item 1.8.8: Contractor is responsible for coordinating fire alarm shut down when conducting hot-work.
  - b. Add item 1.8.9: Temporary heat: Provide temporary heat as required to maintain spaces at a minimum temperature of 10°C.
2. Submittal Procedures, Section 01 33 00:
  - a. Modify item 1.2.12 as follows: In addition to the 6 copies, provide electronic copy in pdf format.

### **Drawings**

3. Drawing M1.02, Mechanical HVAC Barn, Plan and Sections:
- 4.
5. Drawing M3.01, Mechanical HVAC Details & Schedules:
  - a. Roof Top Units Schedule:
    - i) Revise RTU-1, RTU-2 and RTU-3: Add 350mm (14in) high insulated roof curb.
6. Drawing M4.01, Mechanical Specifications (1 of 2)
  - a. Section 15250, Insulation:
    - i) Add item 4: Exterior insulation shall be 50mm thick Armatuff Plus II insulation by Armacell complete with silver finish. Install as per manufacturers recommendations, including provision of slope to the ductwork to allow water to run off the insulation.
7. Drawing M4.02, Mechanical Specifications (2 of 2)
  - a. Add item 6.10: Contractor is responsible for decommissioning and documentation of existing refrigeration equipment (heat pumps) and shall include all records in the O&M Manuals.

2 - The solicitation closing date has changed to Friday October 30, 2015.

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.**