



BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency
National Contracting Service
Bid Receiving Unit
111 Water St. East
Cornwall ON K6H 6S3**

Bid Fax: (877) 558-2349

MODIFICATION No.1

INVITATION TO TENDER

APPEL D'OFFRES

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission à: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaires

Issuing Office - Bureau de distribution

Parks Canada Agency
111 Water St.
Cornwall, ON K6H 6S3

Title - Sujet	
Parc national de l'Î.-P.-É. - Maison Green Gables remplacement des pompes à chaleur	
Solicitation No. - No. de l'invitation 5P300-15-5432	Date 2015 - 10 - 20
GETS Reference No. - No de reference de SEAG PW-15-00702500	
Client Reference No. - No. de référence du client	
Solicitation Closes L'invitation prend fin -	Time Zone Fuseau horaire -
at - à 02:00 PM on - le 2015-10-30	Heure Avancée de l'Est (HNE) / Eastern Daylight Saving Time (EDT)
Address Inquiries to: - Adresser toute demande de renseignements à :	
Michel Marleau michel.marleau@pc.gc.ca	
Telephone No. - No de téléphone (613) 938-5822	Fax No. - No de FAX: (866) 246-6893
Destination of Goods, Services, and Construction: Destination des biens, services et construction:	
Voir dans la présente	

**TO BE COMPLETED BY THE BIDDER
À ÊTRE COMPLÉTÉ PAR LE
SOUMISSIONNAIRE**

Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur :	
Telephone No. - No de téléphone: Facsimile No. - N° de télécopieur:	
Name and title of person authorized to sign on behalf of the Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
_____	_____
Name	Title
_____	_____
Signature	Date

MODIFICATION #1

OBJET DE LA PRÉSENTE MODIFICATION:

1 – Les spécifications doivent être modifiés comme suit (anglais seulement) :

Specifications

1. Summary of Work, Section 01 11 00:
 - a. Add item 1.8.8: Contractor is responsible for coordinating fire alarm shut down when conducting hot-work.
 - b. Add item 1.8.9: Temporary heat: Provide temporary heat as required to maintain spaces at a minimum temperature of 10°C.
2. Submittal Procedures, Section 01 33 00:
 - a. Modify item 1.2.12 as follows: In addition to the 6 copies, provide electronic copy in pdf format.

Drawings

3. Drawing M1.02, Mechanical HVAC Barn, Plan and Sections:
 - 4.
5. Drawing M3.01, Mechanical HVAC Details & Schedules:
 - a. Roof Top Units Schedule:
 - i) Revise RTU-1, RTU-2 and RTU-3: Add 350mm (14in) high insulated roof curb.
6. Drawing M4.01, Mechanical Specifications (1 of 2)
 - a. Section 15250, Insulation:
 - i) Add item 4: Exterior insulation shall be 50mm thick Armatuff Plus II insulation by Armacell complete with silver finish. Install as per manufacturers recommendations, including provision of slope to the ductwork to allow water to run off the insulation.
7. Drawing M4.02, Mechanical Specifications (2 of 2)
 - a. Add item 6.10: Contractor is responsible for decommissioning and documentation of existing refrigeration equipment (heat pumps) and shall include all records in the O&M Manuals.

2 – La date de clôture a changé a vendredi 30 octobre 2015

TOUTES LES AUTRES CONDITIONS GÉNÉRALES DE CETTE DEMANDE RESTENT LES MÊMES