

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
**Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada**
Pacific Region
401 - 1230 Government Street
Victoria, B.C.
V8W 3X4
Bid Fax: (250) 363-3344

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
401 - 1230 Government Street
Victoria, B. C.
V8W 3X4

Title - Sujet CCGS S.W. LAURIER - GEN SETS	
Solicitation No. - N° de l'invitation F1782-15C752/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client F1782-15C752	Date 2015-10-23
GETS Reference No. - N° de référence de SEAG PW-\$XLV-174-6814	
File No. - N° de dossier XLV-5-38103 (174)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-10-29	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Anstey, Gregory	Buyer Id - Id de l'acheteur xlv174
Telephone No. - N° de téléphone (250) 363-0088 ()	FAX No. - N° de FAX (250) 363-3960
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

F1782-15C752/A

Amd. No. - N° de la modif.

004

Buyer ID - Id de l'acheteur

xlv174

Client Ref. No. - N° de réf. du client

F1782-15C752

File No. - N° du dossier

XLV-5-38103

CCC No./N° CCC - FMS No/ N° VME

See attached Part 2

Item	Reference	Solicitation ref.	Specification (SOW)	Bidders questions	Canada answers	Reply Date
1	Solicitation	Annex A	Section 7.1	Will a genset with a prime rating of 568 ekw (625 ekw @ 10% overload) be acceptable?	No, a rating of 568 ekw at 100%load is not acceptable. The minimum acceptable rating is 575 ekW at 100% load. The desired (optimum) genset rating is between 600 ekW and 650 ekW at 100% load.	
2				Can a 730 ekw genset be used if it is the same physical size and displacement as a 700 ekw genset?	Yes, a 730 ekW genset is acceptable.	2015.10.09
3	Solicitation	Annex A	Section 9.1	<p>Ref : " and at a minimum the genset must also be tested at an approved Class Society (per list in paragraph 3.3) facility. "</p> <p>In the absence of an approved Class Society testing facility in Canada, this requirement cannot be met.</p> <p>Considering the following scenario:</p> <ul style="list-style-type: none"> - genset built from an existing commercial design using class type approved/certified components - genset final assembly and combined testing at a ISO9001 facility in Canada - class certification of the generator set through a Design Assessment and test witnessing by an approved Class Society (as well as other witnesses as contractually required) <p>Will Canada consider removing the following section from requirement #9.1?</p> <p>" ...and at a minimum the genset must also be tested at an approved Class Society (per list in paragraph 3.3) facility. "</p>	<p>The genset must not be tested at a Class Society facility.</p> <p>Class certification of the generator set, by an approved Class Society (per list in paragraph 3.4) must be obtained through a Design Assessment and test witnessing by an approved Class Society inspector (as well as other witnesses as contractually required).</p>	2015.10.19

Item	Reference	Solicitation n ref.	Specification n (SOW)	Bidders questions	Canada answers	Reply Date
4	Solicitation	ITT	Section 2.2	The solicitation closes at 2:00 pm on 2015.10.22. The closing date of this solicitation is concurrent with the closing date of solicitation F7049-150105/A on which we are currently actively working. In order to submit a quality proposal to Canada, we request a one calendar week extension to the solicitation period.	A one week extension to 02:00 pm on 2015.10.29 is acceptable to Canada.	2015.10.19
5				The proposed generator set is not off the shelf and will require 7 months production time and up to 6 weeks shipping time after order. Can the latest delivery time be extended to September 15, 2016 with a progress payment clause?	The latest acceptable delivery date is September 15, 2016	2015.10.19
6	Solicitation	ITT	Section 10.2	List of current retail price, lead-time, and part numbers of recommended consumable spares for 2 years and recommended spares for 5 year life cycle maintenance. Please specify the number of hours per year to be used in order to come up with the maintenance schedule-driven list of parts for the specified periods.	The bids must be based on 2,000 running hours per year.	2015.10.22
7	Solicitation			Should SACC clause C3010T be included to provide bidders the opportunity to mitigate against currency exchange rate fluctuation?	Yes. Insert new Article as follows: 3-1.2(1) Exchange Rate Fluctuation C3010T 2014-11-27, Exchange Rate Fluctuation Risk Mitigation	2015.10.22
8	Solicitation			Article 2-1 of the Solicitation refers to an out of date SACC Clause. Please advise?	Revise Article 2-1, in part, to read as follows: “ ... The 2003 (2015-07-03) Standard Instructions...”	
9	Solicitation			Article 6-3.1 of the Solicitation refers to an out of date SACC Clause. Please advise?	Revise Article 6-3.1 to read as follows: 6-3.1 General Conditions 2010A 2015-09-03 , General Conditions - Medium Complexity - Goods, apply to and form part of the Contract.	

10	Solicitation			<p>Paragraph (1) of Section 9 (Warranty) of the 2010A, General Conditions, does not agree with paragraph 12.1 (Warranty) of the Statement of work. Please clarify?</p>	<p>Paragraph (1) of Section 9 (Warranty) of the 2010A, General Conditions, is hereby revised to read as follows:</p> <p>1. Despite inspection and acceptance of the Work by or on behalf of Canada and without restricting any provisions of the Contract or any condition, warranty or provision imposed by law, the Contractor, if requested by Canada to do so, must replace, repair or correct, at its own option and expense any work that becomes defective or fails to conform to the requirements of the Contract, where applicable. The warranty period will be 12 months after delivery and acceptance of the Work or the length of the Contractor's or <i>as stated at paragraph 12.1 (Warranty) of the Statement of Work or</i> manufacturer's standard warranty period, whichever is longer.</p>	
----	--------------	--	--	--	---	--