

PART 1 - GENERAL

- 1.1 REFERENCES**
- .1 National Fire Protection Association (NFPA)
 - .1 NFPA (Fire) 10, Standard for Portable Fire Extinguishers, 2013 Edition.
 - .2 Underwriters Laboratories of Canada (ULC)
 - .1 CAN/ULC S508-02 (R2013), Standard for the Rating and Fire Testing of Fire Extinguishers, Including Amendments 1 and 2.
- 1.2 ACTION AND INFORMATIONAL SUBMITTALS**
- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Closeout Submittals:
 - .1 Provide operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

PART 2 - PRODUCTS

- 2.1 MULTI-PURPOSE DRY CHEMICAL EXTINGUISHERS**
- .1 Stored pressure rechargeable type with hose and shut-off nozzle, ULC labelled for A, B and C class protection.
 - .1 Size 2.25 kg, 3A-10BC rating.
- 2.2 KITCHEN EXTINGUISHERS (CLASS K)**
- .1 Stored pressure rechargeable type ULC labelled for K class protection.
 - .1 Size 6.0 litres, PKD-4-G rating.
- 2.3 EXTINGUISHER BRACKETS**
- .1 Type recommended by extinguisher manufacturer.
- 2.4 CABINETS**
- .1 Flush, surface or semi-recessed type as indicated, constructed of 1.6 mm thick steel, 180 degrees opening door of 2.5 mm thick steel with latching device.
 - .2 Cabinet to maintain fire resistive rating of construction in which they occur.
 - .3 Cabinet door: with 5 mm full glass panel.
 - .4 Finish:
 - .1 Tub: prime coated.
 - .2 Door and frame: No.4 satin finish stainless steel.
- 2.5 IDENTIFICATION**
- .1 Identify extinguishers in accordance with recommendations of NFPA (Fire) 10 CAN/ULC-S508.

PART 3 - EXECUTION**3.1 MANUFACTURER'S** .1
INSTRUCTIONS

Compliance: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION .1

Install or mount extinguishers in cabinets or on brackets as indicated & in accordance with NFPA (Fire) 10.