



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving Public Works and Government**  
**Services Canada/Réception des soumissions**  
**Travaux publics et Services gouvernementaux**  
**Canada**  
**800 Burrard Street, Room 219**  
**800, rue Burrard, pièce 219**  
**Vancouver**  
**British Columbia**  
**V6Z 0B9**  
**Bid Fax: (604) 775-9381**

## **SOLICITATION AMENDMENT**

## **MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### **Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Main Breaker Replacement	
<b>Solicitation No. - N° de l'invitation</b> EZ108-161322/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2015-10-27
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-031-7635	
<b>File No. - N° de dossier</b> PWY-5-38220 (031)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2015-10-29</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Leung, Janie	<b>Buyer Id - Id de l'acheteur</b> pwy031
<b>Telephone No. - N° de téléphone</b> (604) 666-8228 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> NRCan - Pacific Forestry Centre - Victoria, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EZ108-161322/A

Amd. No. - N° de la modif.  
002

Buyer ID - Id de l'acheteur  
PWY031

Client Ref. No. - N° de réf. du client

File No. - N° du dossier  
PWY-5-38220

CCC No./N° CCC - FMS No./N° VME

---

**Les documents français seront disponibles sur demande.**

This Amendment 002 is raised to incorporate Addendum No. 1.

Please see the attached Addendum No. 1.

**All other terms and conditions remain unchanged.**

*The following addendum supersedes information contained in drawings and specifications issued for the project to the extent referenced. This Addendum forms part of the Tender Documents and is subject to all of the conditions set out in the contract conditions.*

This electrical addendum contains seven (7) pages, plus a one (1) page Civil sketch ADD-CIV-01, plus three (3) pages of Specification Section 01 55 00 - Traffic Control, Vehicle Access & Parking, plus Appendix K – twenty five (25) pages, Appendix L – eight (8) pages, Appendix M – five (5) pages, plus a one (1) page revised Table of Contents.

**1. REFER TO DRAWINGS AND SPECIFICATIONS**

- 1.1 The use of DB2 conduit in place of rigid PVC for concrete encased underground duct banks is acceptable.

**The following changes/clarifications in the tender documents are effective immediately. This addendum will form part of the contract documents.**

1. **Question:** Are BC Hydro costs to be covered by the client?

Answer: BC Hydro costs will be paid for directly by the client.

2. **Question:** Has an environmental study been carried out – are there any issues we should be aware of?

There are no known environmental hazards in the areas of work noted.

3. **Question:** New Panel BX-3: Can this be installed on a weekend prior to the main shutdown?

Yes, this can be installed in advance.

4. **Question:** New Panel BX-3: Can the coring (Note 6 E300) be done during normal hours?

There is no issue with coring being done during regular hours, however if it will be protracted ( greater than 30 minutes ) this should be after hours.

5. **Question:** Please clarify how the LV Tech cable for kiosk utility is to be routed together with HV cables through internal pull box (x2) and external pull pit (x1) ensuring code compliance.

This installation has been reviewed and meets code requirements for separation. The Teck cable will be intact from end to end in a fourth conduit. The other three conduits will be used for the 25kV phase conductors.

**END OF ADDENDUM #1**