



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Main Breaker Replacement	
Solicitation No. - N° de l'invitation EZ108-161322/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client	Date 2015-10-27
GETS Reference No. - N° de référence de SEAG PW-\$PWY-031-7635	
File No. - N° de dossier PWY-5-38220 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-10-29	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (604) 666-8228 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: NRCan - Pacific Forestry Centre - Victoria, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ108-161322/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
PWY031

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-5-38220

CCC No./N° CCC - FMS No./N° VME

This Amendment 002 is raised to incorporate Addendum No. 1.

Please see the attached Addendum No. 1.

All other terms and conditions remain unchanged.

The following addendum supersedes information contained in drawings and specifications issued for the project to the extent referenced. This Addendum forms part of the Tender Documents and is subject to all of the conditions set out in the contract conditions.

This electrical addendum contains seven (7) pages, plus a one (1) page Civil sketch ADD-CIV-01, plus three (3) pages of Specification Section 01 55 00 - Traffic Control, Vehicle Access & Parking, plus Appendix K – twenty five (25) pages, Appendix L – eight (8) pages, Appendix M – five (5) pages, plus a one (1) page revised Table of Contents.

1. REFER TO DRAWINGS AND SPECIFICATIONS

- 1.1 The use of DB2 conduit in place of rigid PVC for concrete encased underground duct banks is acceptable.

The following changes/clarifications in the tender documents are effective immediately. This addendum will form part of the contract documents.

1. **Question:** Are BC Hydro costs to be covered by the client?

Answer: BC Hydro costs will be paid for directly by the client.

2. **Question:** Has an environmental study been carried out – are there any issues we should be aware of?

There are no known environmental hazards in the areas of work noted.

3. **Question:** New Panel BX-3: Can this be installed on a weekend prior to the main shutdown?

Yes, this can be installed in advance.

4. **Question:** New Panel BX-3: Can the coring (Note 6 E300) be done during normal hours?

There is no issue with coring being done during regular hours, however if it will be protracted (greater than 30 minutes) this should be after hours.

5. **Question:** Please clarify how the LV Tech cable for kiosk utility is to be routed together with HV cables through internal pull box (x2) and external pull pit (x1) ensuring code compliance.

This installation has been reviewed and meets code requirements for separation. The Teck cable will be intact from end to end in a fourth conduit. The other three conduits will be used for the 25kV phase conductors.

END OF ADDENDUM #1