



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Bid Receiving - PWGSC / Réception des soumissions
- TPSGC**
11 Laurier St. / 11, rue Laurier
Place du Portage, Phase III
Core 0B2 / Noyau 0B2
Gatineau, Québec K1A 0S5
Bid Fax: (819) 997-9776

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Electrical & Electronics Products Division
11 Laurier St./11, rue Laurier
7B3, Place du Portage, Phase III
Gatineau, Québec K1A 0S5

Title - Sujet DOOR CONTROL-SPRINGHILL INSTITUTION	
Solicitation No. - N° de l'invitation 21120-166580/A	Amendment No. - N° modif. 012
Client Reference No. - N° de référence du client 21120-166580	Date 2015-10-29
GETS Reference No. - N° de référence de SEAG PW-\$\$HN-445-67507	
File No. - N° de dossier hn445.21120-166580	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-11-03	Time Zone Fuseau horaire Eastern Standard Time EST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ladouceur, Joanne M.	Buyer Id - Id de l'acheteur hn445
Telephone No. - N° de téléphone (819) 420-0340 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
21120-166580/A
Client Ref. No. - N° de réf. du client
21120-166580

Amd. No. - N° de la modif.
012
File No. - N° du dossier
hn44521120-166580

Buyer ID - Id de l'acheteur
hn445
CCC No./N° CCC - FMS No./N° VME

This amendment 012 is raised to provide a response to a supplier enquiry. The question and response are provided as follows:

=====
Question: Addendum 11 states the relays are to be replaced for living units: 50, 51, 58 and building 5 RRC. In order to confirm relay selection, can a door hardware schedule be provided that includes load requirements of the locks?

Response: Documentation for the existing Springhill Door Control Systems is limited. As per STR 3.2 Scope of work .1 The contractor must carry out a detailed investigation, including a review and analysis of the existing Door control system. It is anticipated that questions of this nature would have been brought up as part of the site visit or very much earlier in the process. In addition, it is CSC's expectation that the supplier will provide the functionality to manage all of the lock types defined in the supporting documentation provided as part of the RFP and that the a Door Hardware Schedule, providing a detailed list of the Door hardware and the type of lock to be managed will be part of the Preliminary Design Report.

=====
Question: Addendum 9 states new fibre is to be provided for buildings 05, 52 and 57. Please confirm that there is sufficient space in the existing conduit for the new fibre runs?

Response: For the bid assume there is sufficient space in the existing conduits and duct banks for buildings 05, 52 and 57. There were 6 new 100mm duct banks installed to support building 52 and 57. Refer to the attached file that was also provided in the recent addendum.

=====
Question: Can an extension of one week from receipt of the door hardware schedule please be granted?

Response: No additional extensions will be granted as a Door Schedule will not be provided.

=====

All other terms and conditions remain unchanged.