



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency
National Contracting Services
111, Water Street East
Cornwall ON K6H 6S3
ATTN: Céline Morin**

QUESTIONS AND ANSWERS NO 1

Tender To: Parks Canada Agency
We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission à : l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency
National Contracting Services
111 Water Street East
Cornwall ON K6H 6S3**

Title-Sujet Atwater Pedestrian Bridge Rehabilitation, Lachine Canal		Date October 30, 2015
Solicitation No. - No. de l'invitation 5P300-15-5461	Client Ref. No. - No. de réf du client.	
GETS Reference No. - No de reference de SEAG 5P300-15-5461		
Solicitation Closes L'invitation prend fin - at - à 02:00 PM on - le 2015-11-10	Time Zone Fuseau horaire - Eastern Standard Time (EST)	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: x Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Céline Morin (celine.morin@pc.gc.ca)		
Telephone No. - No de téléphone 613-938-5940	Fax No. - No de FAX:	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur :		
Telephone No. - No de téléphone: _____		
Facsimile No. - N° de télécopieur: _____		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur		
_____ Name / Nom		_____ Title / Titre
_____ Signature		_____ Date



IS 5P300-15-5461
Atwater Pedestrian Bridge Rehabilitation, Lachine Canal

QUESTIONS AND ANSWERS NO. 1

The following answers are being provided to questions posed by potential bidders:

Q 1 – What specific permits must we obtain for this contract?

R 1 The Contractor must validate all permits required during the work, for example, permits of occupation of public lands delivered by the City of Montreal, for mobilization/demobilization, work and detours. They are responsible for verifying with the appropriate authorities whether any other permits are required.

Must we obtain any permits from Parks Canada?

No, there are no permits to obtain from Parks Canada.

Q 2 – Concerning the signage required to announce the bridge closure, you indicate that four signs are required on the detour road (Annexe 2, section 1500), but on page 4 of section 1500, art 1.12, you ask that one sign be installed. Must we install 4 or 1?

R 2 The Contractor is responsible for ensuring public safety during construction. Consequently, they must respect at a minimum the detour plan in Annex 2. They must determine whether additional signs are required for the duration of the work.

Q 3 – At the site visit, it was mentioned that only part of the steel structure needs to be cleaned and painted during Phase 1. Could you specify which elements must be cleaned and painted?

R 3 The answer to this question will be provided in Addendum 2, which will be posted in the near future.

Q 4 – In section 5123 art 2.1, you indicate that the deck will be provided by CANAM. Must we include the cost of the deck in our bid?

R 4 Yes, the cost of the concrete slab components must be included as shown in the plans. CANAM is a supplier, the Contractor will have to order the deck from CANAM or an approved equivalent.