



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Travaux publics et Services gouvernementaux

Canada

Place Bonaventure, portail Sud-Est

800, rue de La Gauchetière Ouest

7ième étage

Montréal

Québec

H5A 1L6

FAX pour soumissions: (514) 496-3822

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Travaux publics et Services gouvernementaux Canada

Place Bonaventure, portail Sud-Est

800, rue de La Gauchetière Ouest

7ième étage

Montréal

Québec

H5A 1L6

Title - Sujet Installation système de sécurité		
Solicitation No. - N° de l'invitation 47443-165791/A		Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client 47443-16-5791		Date 2015-11-03
GETS Reference No. - N° de référence de SEAG PW-\$MTA-405-13486		
File No. - N° de dossier MTA-5-38090 (405)	CCC No./N° CCC - FMS No./N° VME	
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-11-16		Time Zone Fuseau horaire Heure Normale du l'Est HNE
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Enquiries to: - Adresser toutes questions à: Séguin, Caroline		Buyer Id - Id de l'acheteur mta405
Telephone No. - N° de téléphone (514) 496-3734 ()		FAX No. - N° de FAX (514) 496-3822
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:		

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
47443-165791
Client Ref. No. - N° de réf. du client
47443-16-5791

Amd. No. - N° de la modif.
File No. - N° du dossier
MTA-5-38090

Buyer ID - Id de l'acheteur
mta405
CCC No./N° CCC - FMS No./N° VME

AMENDMENT 02

The purpose of this amendment 02 is to publish Questions and Answers regarding the Request for proposal (RFP).

Questions and Answers

Q1: Could you specify where we can indicate the price for the connections to the controllers of the following items?

- a. Electric strike
- b. Electromagnet
- c. Movement detector
- d. Push button
- e. Re-set key (key switch)

A1: In Annex A "Requirement", section 5A, it is indicated that the control must be adapted to the peripheral equipment already on site. Therefore, the connections must be indicated in the item no. 7 "System installation (including required tests), programming and start-up" of the Annex B "Basis of Payment".

Q2: On page 13 of the solicitation document, section 5A, it is required: "*access control must be coordinated with the automatic door opening system*". Since this requirement implies the provision of an item, can you specify who will supply this item?

A2: The access control contractor will supply the required relay for access control to work with the door opening system.

Q3: Who supplies and installs the cable?

A3: As specified in Annex A "Requirement", section 2 "General description": "*The cabling must be provided by and installed by the supplier*". Therefore, the contractor must provide and install all cables required.

Q4 & Q5: Who provides and installs the conduit? Who provides and installs the junction/electrical boxes?

A4 & A5: The conduits, junction boxes and electrical boxes have already been supplied by the general contractor and installed by the electrical division. The plans provided come from the electrical division for the project and are not specific to access control. They were provided for information purposes.

Q6: On the plans, it is indicated that the architecture division supplies the card readers, but in the specifications it is indicated that these are supplied by the electrical division. Can you please clarify?

A6: The card readers must be supplied by the access control contractor.

Q7: Who supplies the fire alarm relay to interrupt the system?

A7: The fire alarm relay must be provided by the access control contractor.

Solicitation No. - N° de l'invitation
47443-165791
Client Ref. No. - N° de réf. du client
47443-16-5791

Amd. No. - N° de la modif.
File No. - N° du dossier
MTA-5-38090

Buyer ID - Id de l'acheteur
mta405
CCC No./N° CCC - FMS No./N° VME

Q8: Can you specify on which site the programming will take place?

A8: The programming will take place in the adjacent building, located 100 feet from the "Lacolle building".

Q9: It is mentioned that the project includes 20 doors and two of these doors are double. Do we have to install door contacts on each of the double doors? If so, there will be a total of 22 contacts?

A9: A contact must be installed on each door. Therefore, the supplier must install a total of 22 contacts.

Q10: The proximity cards are of what type—standard card, thin card, thin card with unencoded mag stripe, key tag, or adhesive tag?

A10: The proximity cards must be thin cards.

Q11: Regarding the modem, will the controllers be connected through the telephone line? Or are you referring to a Kantech IP link as the communication device?

A11: The controllers will be connected through the telephone line.

Q12: Which software version is installed in the adjacent building?

A12: Entrapass Special Edition 3.18.16.

Q13: How many alarm points (zones), etc. need to be covered by the anti-intrusion alarm system?

A13: The anti-intrusion alarm system must cover 5 zones (4 panic buttons and room C-6.1, as indicated on the "Annex A-1 (modified) - Access Control Plan - Lacolle".

Q14: Should the keypads be LED or alphanumeric? How many partitions?

A14: The keypads must be alphanumeric. The room C-6.1 must be armed at all times except when an authorized person accesses it and disarms it.

All other terms and conditions remain unchanged.