



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works & Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax,(N.E.)
B3J 1T3
Halifax
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.E.)
B3J 3C9
Halifax
Nova Scot

Title - Sujet Grand Pre Church Roof Replacement	
Solicitation No. - N° de l'invitation EB144-161485/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client EB144-16-1485	Date 2015-11-04
GETS Reference No. - N° de référence de SEAG PW-\$PWA-121-5299	
File No. - N° de dossier PWA-5-74107 (121)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-11-10	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Russell (PWA), Alex	Buyer Id - Id de l'acheteur pwa121
Telephone No. - N° de téléphone (902) 496-5168 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

EB144-161485/A

002

pwa121

EB144-16-1485

PWA-5-74107

La modification 002 vise à indiquer ce qui suit :

1. Question: Can man lifts be used on site?

Answer: Because of soft soils with water and service lines buried close to the surface, only scaffold staging can be used to shingle the church. Man lifts can be used only when moving or parked on the rear parking lot by the basement door.

2. Question: Will the National Historic site provide storage for the downspouts that will be removed and re-installed?

Answer: Yes, the National Historic site will allow storage for the downspouts only in the church, and as directed by the Grand Pre Asset Manager.

3. Question: Do the 3 tabs on the shingles need to be sealed to the shingle below?

Answer: Yes, all shingle tabs will be dabbed with roofing cement for adherence to the shingle below.

4. Question: Are longer working days allowed on the site?

Answer: The National Historic site will not unduly hinder the contractor from working longer hours.

5. Question: Are only 3 tabbed shingles allowed in specification 073113 subsection 2.1?

Answer: Only 3 tab shingled will be used.

Toutes les autres conditions demeurent inchangées.