



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving Public Works & Government**  
**Services Canada/Réception des soumissions Travaux**  
**publics et Services gouvernementaux Canada**  
**1713 Bedford Row**  
**Halifax, N.S./Halifax,(N.E.)**  
**B3J 1T3**  
**Halifax**  
**Bid Fax: (902) 496-5016**

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Atlantic Region Acquisitions/Région de l'Atlantique  
Acquisitions  
1713 Bedford Row  
Halifax, N.S./Halifax, (N.E.)  
B3J 3C9  
Halifax  
Nova Scot

<b>Title - Sujet</b> Grand Pre Church Roof Replacement	
<b>Solicitation No. - N° de l'invitation</b> EB144-161485/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> EB144-16-1485	<b>Date</b> 2015-11-04
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWA-121-5299	
<b>File No. - N° de dossier</b> PWA-5-74107 (121)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2015-11-10</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Atlantic Standard Time AST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Russell (PWA), Alex	<b>Buyer Id - Id de l'acheteur</b> pwa121
<b>Telephone No. - N° de téléphone</b> (902) 496-5168 ( )	<b>FAX No. - N° de FAX</b> (902) 496-5016
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

EB144-161485/A

002

pwa121

EB144-16-1485

PWA-5-74107

---

**Amendment 002 is raised for the following:**

1. Question: Can man lifts be used on site?

Answer: Because of soft soils with water and service lines buried close to the surface, only scaffold staging can be used to shingle the church. Man lifts can be used only when moving or parked on the rear parking lot by the basement door.

2. Question: Will the National Historic site provide storage for the downspouts that will be removed and re-installed?

Answer: Yes, the National Historic site will allow storage for the downspouts only in the church, and as directed by the Grand Pre Asset Manager.

3. Question: Do the 3 tabs on the shingles need to be sealed to the shingle below?

Answer: Yes, all shingle tabs will be dabbed with roofing cement for adherence to the shingle below.

4. Question: Are longer working days allowed on the site?

Answer: The National Historic site will not unduly hinder the contractor from working longer hours.

5. Question: Are only 3 tabbed shingles allowed in specification 073113 subsection 2.1?

Answer: Only 3 tab shingled will be used.

**All other terms and conditions remain the same.**