

PART 1 **GENERAL**

1.1 **SECTION INCLUDES**

- .1 Materials for moulded-case circuit breakers, circuit breakers, and ground-fault circuit-interrupters.
- .2 Text to complete:
 - .1 Section 26 23 00 – Low Voltage Switchgear
 - .2 Section 26 28 18 – Ground Fault Equipment Protection
 - .3 Section 26 24 16.01 – Panelboards Breaker Type.

1.2 **RELATED REQUIREMENTS**

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 19 – Construction Waste Management and Disposal.
- .3 Section 26 23 00 – Low Voltage Switchgear.
- .4 Section 26 28 18 – Ground Fault Equipment Protection.
- .5 Section 26 24 16.01 – Panelboards Breaker Type.

1.3 **REFERENCES**

- .1 Canadian Standards Association (CSA International)
 - .1 CSA-C22.2 No. 5-02, Moulded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures (Tri-national standard with UL 489, tenth edition, and the second edition of NMX-J-266-ANCE).

1.5 **WASTE MANAGEMENT AND DISPOSAL**

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Collect and separate for disposal paper, plastic, polystyrene and corrugated cardboard packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .3 Separate for reuse and recycling and place in designated containers Steel Metal Plastic waste in accordance with Waste Management Plan

PART 2 **PRODUCTS**

2.1 **BREAKERS GENERAL**

- .1 Moulded-case circuit breakers, Circuit breakers, and Ground-fault circuit-interrupters, Fused circuit breakers, and Accessory high-fault protectors: to CSA C22.2 No. 5.

- .2 Bolt-on moulded case circuit breaker: quick- make, quick-break type, for manual and automatic operation with temperature compensation for 40 degrees C ambient.
- .4 Common-trip breakers: with single handle for multi-pole applications
- .5 Magnetic instantaneous trip elements in circuit breakers to operate only when value of current reaches setting.
 - .1 Trip settings on breakers with adjustable trips to range from 3-8 times current rating.
- .6 Circuit breakers with interchangeable trips as indicated.
- .7 Circuit breakers to have minimum 14,000 amps symmetrical rms interrupting capacity rating, if not indicated otherwise.

2.2 THERMAL MAGNETIC BREAKERS

- .1 Moulded case circuit breaker to operate automatically by means of thermal and magnetic tripping devices to provide inverse time current tripping and instantaneous tripping for short circuit protection.
- .2 Use thermal magnetic breakers for branch circuit protection and main breaker in all panel boards.

2.3 MAGNETIC BREAKERS

- .1 Moulded case circuit breaker to operate automatically by means of magnetic tripping devices to provide instantaneous tripping for short circuit protection.
- .2 Use magnetic breakers for panel board breakers where indicated.

2.4 CURRENT LIMITING AND SERIES RATED THERMAL MAGNETIC BREAKERS DESIGN C

- .1 Thermal magnetic breakers with current limiters.
 - .1 Time current limiting characteristics of fuses limiters coordinated with time current tripping characteristics of circuit breaker.
 - .2 Co-ordination to result in interruption by breaker of fault-level currents up to interrupting capacity of breaker.

2.5 SOLID STATE TRIP BREAKERS

- .1 Moulded case circuit breaker to operate by means of solid-state trip unit with associated current monitors and self-powered shunt trip to provide inverse time current trip under overload condition, and long time short time instantaneous tripping for phase ground fault short circuit protection.
- .2 Use solid state trip breakers for all breakers in the Low Voltage Switchgear Distribution Section and distribution boards.

2.6 OPTIONAL FEATURES

- .1 Include where indicated:
 - .1 Shunt trip.
 - .2 Auxiliary Switch.
 - .3 Motor-operated mechanism.
 - .4 Under-voltage release.
 - .5 On-off locking device.
 - .6 Handle mechanism.

2.7 ENCLOSURE

 All breakers to be mounted in equipment as indicated.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Install circuit breakers as indicated.

END OF SECTION