
PART 1 **GENERAL**

1.1 **SUMMARY**

- .1 Section Includes.
 - .1 Requirements and procedures for warranty and activities during warranty period and service contracts, for building Energy Monitoring and Control System (EMCS).

1.2 **RELATED SECTIONS**

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 78 00 - Closeout Submittals.
- .3 Section 25 05 01 - EMCS: General Requirements.

1.3 **REFERENCES**

- .1 Canada Labour Code (R.S., c. L-2)/Part I - Industrial Relations.
- .2 Canadian Standards Association (CSA)
 - .1 CSA Z204 – Guidelines for Managing Indoor Quality in Buildings

1.4 **DEFINITIONS**

- .1 OWS - Operator Work Station.
- .2 For additional acronyms and definitions refer to Section 25 05 01 - EMCS: General Requirements.

1.5 **SUBMITTALS**

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit detailed preventative maintenance schedule for system components to Department Representative.
- .3 Submit detailed inspection reports Owner's Representative.
- .4 Submit dated, maintenance task lists to Owner's Representative and include the following sensor and output point detail, as proof of system verification:
 - .1 Point name and location.
 - .2 Device type and range.
 - .3 Measured value.
 - .4 System displayed value.
 - .5 Calibration detail
 - .6 Indication if adjustment required,

- .7 Other action taken or recommended.
- .5 Submit network analysis report showing results with detailed recommendations to correct problems found.
- .6 Records and logs: in accordance with Section 01 78 00 - Closeout Submittals.
 - .1 Maintain records and logs of each maintenance task on site.
 - .2 Organize cumulative records for each major component and for entire EMCS chronologically.
 - .3 Submit records to Department Representative, after inspection indicating that planned and systematic maintenance have been accomplished.
- .7 Revise and submit to Department Representative in accordance with Section 01 78 00 - Closeout Submittals "As-built drawings" documentation and commissioning reports to reflect changes, adjustments and modifications to EMCS made during warranty period.

1.6 MAINTENANCE SERVICE DURING WARRANTY PERIOD

- .1 Provide services, materials, and equipment to maintain EMCS for warranty period of one year after date of substantial completion. Provide detailed preventative maintenance schedule for system components as described in Submittal article.
- .2 Emergency Service Calls:
 - .1 Initiate service calls when EMCS is not functioning correctly.
 - .2 Qualified control personnel to be available during warranty period to provide service to "CRITICAL" components whenever required at no extra cost.
 - .3 Furnish Department Representative with telephone number where service personnel may be reached at any time.
 - .4 Service personnel to be on site ready to service EMCS after receiving request for service.
 - .5 Perform work continuously until EMCS restored to reliable operating condition.
- .3 Operation: foregoing and other servicing to provide proper sequencing of equipment and satisfactory operation of EMCS based on original design conditions and as recommended by manufacturer.
- .4 Work requests: record each service call request, when received separately on approved form and include:
 - .1 Serial number identifying component involved.
 - .2 Location, date and time call received.
 - .3 Nature of trouble.
 - .4 Names of personnel assigned.
 - .5 Instructions of work to be done.
 - .6 Amount and nature of materials used.
 - .7 Time and date work started.

.8 Time and date of completion.

.5 Provide system modifications in writing.

.1 No system modification, including operating parameters and control settings, to be made without prior written approval of Department Representative.

1.7 SERVICE CONTRACTS

.1 Provide in-depth technical expertise and assistance to Department Representative and Commissioning Manager in preparation and implementation of service contracts and in-house preventive maintenance procedures. Service contracts duration is for the warranty period.

.2 Service Contracts to include:

.1 Annual verification of field points for operation and calibration.

.2 4 visits per year.

.3 2 responses to emergency calls during day, per year.

.4 2 responses to emergency calls during silent hours, per year.

.5 Silent hours defined as 1630 h – 0800 h and on weekends and statutory holidays.

.6 Complete inventory of installed system.

PART 2 PRODUCTS (NOT USED)

PART 3 EXECUTION

3.1 FIELD QUALITY CONTROL

.1 Perform as minimum (3) three minor inspections and one major inspection (more often if required by manufacturer) per year. Provide detailed written report to Department Representative as described in Submittal article.

.2 Perform inspections during regular working hours, 0800 to 1630 h, Monday through Friday, excluding statutory holidays.

.3 Following inspections are minimum requirements and should not be interpreted to mean satisfactory performance:

.1 Perform calibrations using test equipment having traceable, certifiable accuracy at minimum 50% greater than accuracy of system displaying or logging value.

.2 Check and calibrate random sample of 10% field input/output devices in accordance with Canada Labour Code - Part I and CSA Z204.

.3 Provide dated, maintenance task lists, as proof of execution of complete system verification.

.4 Minor inspections to include, but not limited to:

- .1 Perform visual, operational checks to BC's, peripheral equipment, interface equipment and other panels.
- .2 Check equipment cooling fans as required.
- .3 Visually check for mechanical faults, air leaks and proper pressure settings on pneumatic components.
- .4 Review system performance with Department Representative to discuss suggested or required changes.
- .5 Major inspections to include, but not limited to:
 - .1 Minor inspection.
 - .2 Clean OWS(s) peripheral equipment, BC(s), interface and other panels, micro-processor interior and exterior surfaces.
 - .3 Check signal, voltage and system isolation of BC(s), peripherals, interface and other panels.
 - .4 Verify calibration/accuracy of each input and output device and recalibrate or replace as required (as per 3.1. 3.2).
 - .5 Provide mechanical adjustments, and necessary maintenance on printers.
 - .6 Run system software diagnostics as required.
 - .7 Install software and firmware enhancements to ensure components are operating at most current revision for maximum capability and reliability.
 - .1 Perform network analysis and provide report as described in Submittal article.
- .6 Rectify deficiencies revealed by maintenance inspections and environmental checks.
- .7 Continue system debugging and optimization.
- .8 Testing/verification of occupancy and seasonal-sensitive systems to take place during four (4) consecutive seasons, after facility has been accepted, taken over and fully occupied.
 - .1 Test weather-sensitive systems twice: first at near winter design conditions and secondly under near summer design conditions.

END OF SECTION