



- NOTES:
1. UNLESS OTHERWISE INDICATED ALL POWER RECEPTACLES, DATA AND TELEPHONE OUTLETS, BASEBOARD HEATERS, CABINET HEATERS, LIGHT FIXTURES, EXIT LIGHTS, SURFACE RACEWAY, LIGHT SWITCHES, POWER PACK POLES, SPEAKER AND ASSOCIATED WIRE, BOXES AND CONDUITS TO BE REMOVED. REMOVE ALL ABANDONED WIRE AND CONDUIT.
 2. ALL SERVICES IN THIS ROOM TO REMAIN UNLESS OTHERWISE INDICATED.
 3. REMOVE PERIMETER HEATING SCR'S AND ASSOCIATED WIRE AND CONDUIT.
 4. WHERE EXISTING DUCT HEATING COILS ARE REMOVED ELECTRICAL CONTRACTOR TO REMOVE ASSOCIATED WIRE, CONDUIT AND BOXES.

5. MAJORITY OF LIGHTING FOR LEVEL 2 POD G18 IS CONTROLLED VIA EXISTING LIGHTING CONTROL RELAY PANEL IN ROOM G18-233. LIGHTING FOR THE NEW RENOVATED AREA IS TO BE DISCONNECTED FROM THIS RELAY PANEL AND CONNECTED AND CONTROLLED AS PER DETAILS 1, 2 AND 3 LOCATED ON SHEET E1. ALL OTHER LIGHTING AND ITS CONTROL TO REMAIN.

SCALE: 1:50
0m 1m 2m 3m 4m 5m

Public Works and Government Services Canada
Travaux Publics et Services gouvernementaux Canada



4	REVISED ISSUED FOR TENDER	09/28/2015
1	REVISED ISSUED FOR TENDER	04/07/2014
A	ISSUED FOR TENDER	03/24/2014
0	ISSUED FOR REVIEW	02/28/2014
revisions		date

project

**G18 LEVEL 2
INTERIOR RENOVATIONS
NORTHWEST ATLANTIC
FISHERIES CENTRE
St. John's, NL**

drawing

**ELECTRICAL
DEMOLITION FLOOR PLAN**

designed G.N.S. conçu

date FEB. 2014

drawn G.N.S. dessiné

date FEB. 2014

approved

date

Tender 14-02-28

PWGSC Project Manager Administrateur de projets TPSGC

project number no. du projet

R068178.001

drawing no. no. du dessin

E02

E-DRM/GDD-E 530593