

---

**PART 1        GENERAL**

**1.1            SUMMARY**

- .1        Section Includes:
  - .1            Materials and installation for duct accessories including flexible connections, access doors, vanes and collars.

**1.2            RELATED SECTIONS**

- .1        Section 01 33 00 – Submittal Procedures.
- .2        Section 01 45 00 – Quality Control.
- .3        Section 01 74 21 – Construction/Demolition Waste Management and Disposal.
- .4        Section 01 78 00 – Closeout Submittals.

**1.3            REFERENCES**

- .1        Health Canada/Workplace Hazardous Materials Information System (WHMIS).
  - .1            Material Safety Data Sheets (MSDS).
- .2        Sheet Metal and Air Conditioning Contractors' National Association (SMACNA).
  - .1            SMACNA – HVAC Duct Construction Standards – Metal and Flexible.

**1.4            SUBMITTALS**

- .1        Submittals in accordance with Section 01 33 00 – Submittal Procedures.
- .2        Product Data:
  - .1            Submit manufacturer's printed product literature, specifications and data sheet. Indicate the following:
    - .1            Flexible connections
    - .2            Duct access doors.
    - .3            Turning vanes.
    - .4            Instrument test ports.
- .3        Test Reports: submit certified test reports from approved independent testing laboratories indicating compliance with specifications for specified performance characteristics and physical properties.
  - .1            Certification of ratings: catalogue or published ratings to be those obtained from tests carried out by manufacturer or independent testing agency signifying adherence to codes and standards.

- .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Instructions: submit manufacturer's installation instructions.
- .6 Manufacturer's Field Reports: manufacturer's field reports specified.
- .7 Closeout Submittals: submit maintenance and engineering data for incorporation into manual specified in Section 01 78 00 – Closeout Submittals.

## **1.5 QUALITY ASSURANCE**

- .1 Pre-Installation Meetings:
  - .1 Convene pre-installation meeting one week prior to beginning work of this Section and on-site installations.
    - .1 Verify project requirements.
    - .2 Review installation and substrate conditions.
    - .3 Co-ordination with other building subtrades.
    - .4 Review manufacturer's installation instructions and warranty requirements.

## **1.6 DELIVERY, STORAGE AND HANDLING**

- .1 Waste Management and Disposal:
  - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 – Construction/Demolition Waste Management and Disposal.
  - .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
  - .3 Collect and separate for disposal paper, plastic, polystyrene, and corrugated cardboard, packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan (WMP).
  - .4 Separate for reuse and recycling and place in designated containers steel, metal, and plastic waste in accordance with Waste Management Plan (WMP).
  - .5 Divert unused metal materials from landfill to metal recycling facility as approved by Department Representative.

## **PART 2 PRODUCTS**

### **2.1 GENERAL**

- .1 Manufacture in accordance with SMACNA - HVAC Duct Construction Standards.

## **2.2 FLEXIBLE CONNECTIONS**

- .1 Frame: galvanized sheet metal frame 0.66 mm thick with fabric clenched by means of double locked seams.
- .2 Material:
  - .1 Fire resistant, self extinguishing, neoprene coated glass fabric, temperature rated at minus 40<sup>0</sup>C to plus 90<sup>0</sup>C, density of 1.3 kg/m<sup>2</sup>.

## **2.3 ACCESS DOORS IN DUCTS**

- .1 Non-insulated ducts: sandwich construction of same material as duct, one sheet metal thickness heavier, minimum 0.6 mm thick complete with sheet metal angle frame.
- .2 Insulated ducts: sandwich construction of same material as duct, one sheet metal thickness heavier, minimum 0.6 mm thick complete with sheet metal angle frame and 25 mm thick rigid glass fibre insulation.
- .3 Gaskets: neoprene.
- .4 Hardware:
  - .1 Hold open devices.
  - .2 300 x 300 mm glass viewing panels.
  - .3 Up to 300 x 300 mm: two sash locks complete with safety chain.
  - .4 301 to 450 mm: four sash locks complete with safety chain.
  - .5 451 to 1000 mm: piano hinge and minimum two sash locks.
  - .6 Doors over 1000 mm: piano hinge and two handles operable from both sides.
    - .1 Hold open devices.
    - .2 300 X 300 mm glass viewing panels.

## **2.4 TURNING VANES**

- .1 Factory or shop fabricated double thickness with trailing edge, to recommendations of SMACNA and as indicated.

## **2.5 INSTRUMENT TEST PORTS**

- .1 1.6 mm thick steel zinc plated after manufacture.
- .2 Cam lock handles with neoprene expansion plug and handle chain.
- .3 28 mm minimum inside diameter. Length to suit insulation thickness.
- .4 Neoprene mounting gasket.

## **2.6 SPIN-IN COLLARS**

- .1 Conical galvanized sheet metal spin-in collars with lockable butterfly damper.
- .2 Sheet metal thickness to co-responding round duct standards.

## **PART 3 EXECUTION**

### **3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

### **3.2 INSTALLATION**

- .1 Flexible connections:
  - .1 Install in following locations:
    - .1 Inlets and outlets to supply air units and fans.
    - .2 Inlets and outlets of exhaust and return air fans.
    - .3 As indicated.
  - .2 Length of connection: 100 mm.
  - .3 Minimum distance between metal parts when system in operation: 75 mm.
  - .4 Install in accordance with recommendations of SMACNA.
  - .5 When fan is running:
    - .1 Ducting on sides of flexible connection to be in alignment.
    - .2 Ensure slack material in flexible connection.
- .2 Access doors and viewing panels:
  - .1 Size:
    - .1 600 x 600 mm for person size entry.
    - .2 450 x 450 mm for servicing entry.
    - .3 300 x 300 mm for viewing.
    - .4 As indicated.
  - .2 Locations:
    - .1 Fire and smoke dampers.
    - .2 Control dampers.
    - .3 Devices requiring maintenance.
    - .4 Required by code.
    - .5 Reheat coils.
    - .6 Elsewhere as indicated.
- .3 Instrument test ports.

- .1 General:
  - .1 Install in accordance with recommendations of SMACNA and in accordance with manufacturer's instructions.
  - .2 Locate to permit easy manipulation of instruments.
  - .3 Install insulation port extensions as required.
  - .4 Locations.
    - .1 For traverse readings:
      - .1 Ducted inlets to roof and wall exhausters.
      - .2 Inlets and outlets of other fan systems.
      - .3 Main and sub-main ducts.
      - .4 And as indicated.
    - .2 For temperature readings:
      - .1 At outside air intakes.
      - .2 In mixed air applications in locations as approved by Owner's Representative.
      - .3 At inlet and outlet of coils.
      - .4 Downstream of junctions of two converging air streams of different temperatures.
      - .5 And as indicated.
- .4 Turning vanes:
  - .1 Install in accordance with recommendations of SMACNA and as indicated.

### 3.3 FIELD QUALITY CONTROL

- .1 Manufacturer's Field Services:
  - .1 Have manufacturer's representative of products, supplied under this Section, review Work involved in the handling, installation/application, protection and cleaning, of its products and submit written reports, in acceptable format, to verify compliance of Work with Contract.
  - .2 Manufacturer's Field Services: provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
  - .3 Schedule site visits, to review Work, at stages listed:
    - .1 After delivery and storage of products, and when preparatory Work, or other Work, on which the Work of this Section depends, is complete but before installation begins.
    - .2 Twice during progress of Work at 25% and 60% complete.
    - .3 Upon completion of the Work, after cleaning is carried out.
  - .4 Obtain reports, within 3 days of review, and submit, immediately, to Owner's Representative.

---

**3.4 CLEANING**

- .1 Perform cleaning operations as specified in Section 01 74 11 – Cleaning and in accordance with Manufacturer’s recommendations.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

**END OF SECTION**