

PART 1 GENERAL

1.1 SUMMARY

.1 Section Includes:

- .1 Fire and smoke dampers, and fire stop flaps.**

1.2 RELATED SECTIONS

- .1 Section 01 33 00 – Submittal Procedures.**
- .2 Section 01 74 21 – Construction/Demolition Waste Management and Disposal.**
- .3 Section 23 31 13.01 – Metal Ducts – Low Pressure to 500 Pa.**

1.3 REFERENCES

- .1 American National Standards Institute/National Fire Protection Association (ANSI/NFPA)**
 - .1 ANSI/NFPA 90A, Standard for the Installation of Air Conditioning and Ventilating Systems.**
- .2 Health Canada/Workplace Hazardous Materials Information System (WHMIS)**
 - .1 Material Safety Data Sheets (MSDS).**
- .3 Underwriters Laboratories of Canada (ULC)**
 - .1 CAN4-S112, Fire Test of Fire Damper Assemblies.**
 - .2 CAN4-S112.2, Standard Method of Fire Test of Ceiling Firestop Flap Assemblies.**
 - .3 ULC-S505, Fusible Links for Fire Protection Service.**

1.4 SUBMITTALS

.1 Product Data:

- .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.**
 - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.**
- .2 Indicate the following:**
 - .1 Fire dampers.**
 - .2 Smoke dampers.**
 - .3 Fire stop flaps.**

- .4 Operators.
 - .5 Fusible links.
 - .6 Design details of break-away joints.
- .2 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.
- .3 Closeout Submittals:
 - .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals

1.5 QUALITY ASSURANCE

- .1 Certificates:
 - .1 Catalogue or published ratings those obtained from tests carried out by manufacturer or those ordered by manufacturer from independent testing agency signifying adherence to codes and standards.

1.6 MAINTENANCE

- .1 Extra Materials:
 - .1 Provide maintenance materials in accordance with Section 01 78 00 – Closeout Submittals.
 - .2 Provide the following:
 - .1 6 fusible links of each type.

1.7 DELIVERY, STORAGE, AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 PRODUCTS

2.1 FIRE DAMPERS

- .1 Fire dampers: arrangement Type B or C, blades out of air stream listed and bear label of ULC, meet requirements of provincial fire authority and ANSI/NFPA 90A. Fire damper assemblies to be fire tested in accordance with CAN4-S112. Minimum rating 1 ½ hours, dynamically rated.
- .2 Mild steel, factory fabricated for fire rating requirement to maintain integrity of fire wall and/or fire separation.
- .3 Top hinged: offset, round or square; multi-blade hinged or interlocking type; roll door type; or guillotine type; sized to maintain full duct cross section.
- .4 Fusible link actuated, weighted to close and lock in closed position when released or having negator-spring-closing operator for multi-leaf type or roll door type in horizontal position with vertical air flow.
- .5 Retaining angle iron frame, 40 x 40 x 3 mm, on full perimeter of fire damper, on both sides of fire separation being pierced.
- .6 Equip fire dampers with steel sleeve or frame installed to prevent disruption of ductwork or impair damper operation.
- .7 Equip sleeves or frames with perimeter mounting angles attached on both sides of wall or floor opening. Construct ductwork in fire-rated floor-ceiling or roof-ceiling assembly systems with air ducts that pierce ceiling to conform with ULC.
- .8 Design and construct dampers to not reduce duct or air transfer opening cross-sectional area.
- .9 Dampers shall be installed so that the centerline of the damper depth or thickness is located in the centerline of the wall, partition or floor slab depth or thickness.
- .10 Unless otherwise indicated, the installation details given in SMACNA Fire, Smoke, and Radiation Damper Installation Guide for HVAC and in manufacturer's instructions for fire dampers shall be followed.

2.2 SMOKE DAMPERS

- .1 To be ULC or UL listed and labelled.
- .2 Normally closed reverse action smoke vent (S/D-RASV): folding blade type, opening by gravity upon detection of smoke, and/or from remote alarm signalling device actuated by an electro thermal link. Two flexible stainless steel blade edge seals to provide required constant sealing pressure.

- .3 Normally open smoke/seal (S/D-SSSD): folding blade type, closing when actuated by means of electro thermal link and/or from remote alarm signalling device. Blade edge seals of flexible stainless steel shall provide required constant sealing pressure. Stainless steel negator springs with locking devices shall ensure positive closure for units mounted horizontally in vertical ducts.
- .4 Motorized (S/D-M): folding blade type, normally open with power on. When power is interrupted damper shall close automatically. Both damper and damper operator shall be ULC listed and labelled.
- .5 Electro thermal link (S/D-ETL): dual responsive fusible link which melts when subjected to local heat of 74 EC and from external electrical impulse of low power and short duration; ULC or UL listed and labelled.

2.3 COMBINATION FIRE AND SMOKE DAMPERS

- .1 Damper: similar in all respects to smoke dampers specified above.
- .2 Combined actuator: electrical control system actuated from smoke sensor or smoke detection system and from fusible link.

2.4 FIRE STOP FLAPS

- .1 To be ULC listed and labelled and fire tested in accordance with CAN4-S112.2.
- .2 Construct of minimum 1.5 mm thick sheet steel with 1.6 mm thick non-asbestos ULC listed insulation and corrosion-resistant pins and hinges.
- .3 Flaps to be held open with fusible link conforming to ULC-S505 and close at 74 EC.

PART 3 EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install in accordance with ANSI/NFPA 90A and in accordance with conditions of ULC listing.
- .2 Maintain integrity of fire separation.
- .3 After completion and prior to concealment obtain approvals of complete installation from authority having jurisdiction.

- .4 Install access door adjacent to each damper. See Section 23 33 00 – Air Duct Accessories.
- .5 Coordinate with installer of firestopping to Section 07 84 00 – Firestopping.
- .6 Ensure access doors/panels, fusible links, damper operators are easily observed and accessible.
- .7 Install break-away joints of approved design on each side of fire separation.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION