

---

## **PART 1        GENERAL**

### **1.1        SUMMARY**

- .1        Section Includes:
  - .1        Materials and requirements for the identification of piping systems, duct work, valves and controllers, including the installation and location of identification systems.
  - .2        Sustainable requirements for construction and verification.

### **1.2        RELATED SECTIONS**

- .1        Section 01 33 00 - Submittal Procedures.
- .2        Section 01 74 21 – Construction/Demolition Waste Management and Disposal
- .3        Section 09 91 23 - Interior Painting.

### **1.3        REFERENCES**

- .1        Canadian Gas Association (CGA)
  - .1        CSA/CGA B149.1, Natural Gas and Propane Installation Code.
  - .2        CSAZ7396.1 Medical Gas pipeline Systems – Part 1: Pipelines for medical gases and vacuum.
- .2        Canadian General Standards Board (CGSB)
  - .1        CAN/CGSB-1.60, Interior Alkyd Gloss Enamel.
  - .2        CAN/CGSB-24.3, Identification of Piping Systems.
- .3        National Fire Protection Association (NFPA)
  - .1        NFPA 13, Standard for the Installation of Sprinkler Systems.
  - .2        NFPA 14, Standard for the Standpipe and Hose Systems.

### **1.4        SUBMITTALS**

- .1        Product Data:
  - .1        Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
  - .2        Product data to include paint colour chips, other products specified in this section.
  - .3        Samples:
    - .1        Submit samples in accordance with Section 01 33 00 – Submittal Procedures.
    - .2        Samples to include nameplates, labels, tags, lists of proposed legends.

## **1.5 QUALITY ASSURANCE**

- .1 Quality assurance submittals: submit following in accordance with Section 01 33 00 – Submittal Procedures.

## **1.6 DELIVERY, STORAGE, AND HANDLING**

- .1 Packing, shipping, handling and unloading:
  - .1 Deliver, store and handle in accordance with Section 01 61 00 – Common Product Requirements.
  - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
  - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
  - .2 Dispose of unused paint coating material at official hazardous material collections site approved by Engineer / Architect.
  - .3 Do not dispose of unused paint coating material into sewer system, into streams, lakes, onto ground or in locations where it will pose health or environmental hazard.

## **PART 2 PRODUCTS**

### **2.1 MANUFACTURER'S EQUIPMENT NAMEPLATES**

- .1 Metal or plastic laminate nameplate mechanically fastened to each piece of equipment by manufacturer.
- .2 Lettering and numbers to be raised or recessed.
- .3 Information to include, as appropriate:
  - .1 Equipment: Manufacturer's name, model, size, serial number, capacity.
  - .2 Motor: voltage, Hz, phase, power factor, duty, frame size.

### **2.2 SYSTEM NAMEPLATES**

- .1 Colours:
  - .1 Hazardous: red letters, white background.
  - .2 Elsewhere: black letters, white background (except where required otherwise by applicable codes).
- .2 Construction:
  - .1 3 mm thick laminated plastic or white anodized aluminum, matte finish, with square corners, letters accurately aligned and machine engraved into core.

.3 Sizes:

.1 Conform to following table:

Size # mm	Sizes (mm)	No. of Lines	Height of Letters (mm)
1	10 x 50	1	3
2	13 x 75	1	5
3	13 x 75	2	3
4	20 x 100	1	8
5	20 x 100	2	5
6	20 x 200	1	8
7	25 x 125	1	12
8	25 x 125	2	8
9	35 x 200	1	20

.2 Use maximum of 25 letters/numbers per line.

.4 Locations:

.1 Terminal cabinets, control panels: Use size # 5.

.2 Equipment in Mechanical Rooms: Use size # 9.

## 2.3 EXISTING IDENTIFICATION SYSTEMS

.1 Apply existing identification system to new work.

.2 Where existing identification system does not cover for new work, use identification system specified this section.

.3 Before starting work, obtain written approval of identification system from Department Representative.

## 2.4 PIPING SYSTEMS GOVERNED BY CODES

.1 Identification:

.1 Natural gas: to CSA/CGA B149.1, authority having jurisdiction.

.2 Propane gas: to CSA/CGA B149.1 authority having jurisdiction.

.3 Sprinklers: to NFPA 13.

.4 Standpipe and hose systems: to NFPA 14.

.5 Medical Gas: to CAN/CSA Z7396.1.

## 2.5 IDENTIFICATION OF PIPING SYSTEMS

.1 Identify contents by background colour marking, pictogram (as necessary), legend; direction of flow by arrows. To CAN/CGSB 24.3 except where specified otherwise.

.2 Pictograms:

- .1 Where required, to Workplace Hazardous Materials Information System (WHMIS) regulations.
- .3 Legend:
  - .1 Block capitals to sizes and colours listed in CAN/CGSB 24.3.
- .4 Arrows showing direction of flow:
  - .1 Outside diameter of pipe or insulation less than 75 mm: 100 mm long x 50 mm high.
  - .2 Outside diameter of pipe or insulation 75 mm and greater: 150 mm long x 50 mm high.
  - .3 Use double-headed arrows where flow is reversible.
- .5 Extent of background colour marking:
  - .1 To full circumference of pipe or insulation.
  - .2 Length to accommodate pictogram, full length of legend and arrows.
- .6 Materials for background colour marking, legend, arrows:
  - .1 Pipes and tubing 20 mm and smaller: Waterproof and heat-resistant pressure sensitive plastic marker tags.
  - .2 All other pipes: Pressure sensitive plastic-coated cloth or vinyl with protective overcoating, waterproof contact adhesive undercoating, suitable for ambient of 100%RH and continuous operating temperature of 150°C and intermittent temperature of 200°C.
- .7 Colours and Legends:
  - .1 Where not listed, obtain direction from Department Representative.
  - .2 Colours for legends, arrows, to following table:

Background colour	Legend, arrows
Yellow	BLACK
Green	WHITE
Red	WHITE

- .3 Background colour marking and legends for piping systems:

Contents	Background colour marking	Legend
** Add design temperature		
++ Add design temperature and pressure		
Raw water	Green	RAW WATER
River water	Green	RIVER WATER
Sea water	Green	SEA WATER
City water	Green	CITY WATER
Treated water	Green	TREATED WATER
Brine	Green	BRINE
Condenser water supply	Green	COND. WTR. SUPPLY

Contents	Background colour marking	Legend
** Add design temperature		
++ Add design temperature and pressure		
Condenser water return	Green	COND. WTR. RETURN
Chilled water supply	Green	CH. WTR. SUPPLY
Chilled water return	Green	CH. WTR. RETURN
Hot water heating supply	Yellow	HEATING SUPPLY
Hot water heating return	Yellow	HEATING RETURN
High temp HW Htg. supply	Yellow	HTHW HTG. SUPPLY++
High temp HW Htg. return	Yellow	HTHW HTG. RETURN++
Make-up water	Yellow	MAKE-UP WTR
Boiler feed water	Yellow	BLR. FEED WTR
Steam ____kPa	Yellow	____kPa STEAM
Steam condensate (gravity)	Yellow	ST.COND.RET (GRAVITY)
Steam condensate (pumped)	Yellow	ST.COND.RET (PUMPED)
Safety valve vent	Yellow	STEAM VENT
Intermittent blow-off	Yellow	INT. BLOW-OFF
Continuous blow-off	Yellow	CONT. BLOW-OFF
Chilled drinking water	Green	CH. DRINK WTR
Drinking water return	Green	CH. DRINK WTR. CIRC
Domestic hot water supply	Green	DOM. HW SUPPLY
Dom. HWS recirculation	Green	DOM. HW CIRC
Domestic cold water supply	Green	DOM. CWS
Waste water	Green	WASTE WATER
Contaminated lab waste	Yellow	CONT. LAB WASTE
Acid waste	Yellow	ACID WASTE (add source)
Storm water	Green	STORM
Sanitary	Green	SAN
Plumbing vent	Green	SAN. VENT
Refrigeration suction	Yellow	REF. SUCTION
Refrigeration liquid	Yellow	REF. LIQUID
Refrigeration hot gas	Yellow	REF. HOT GAS
No. ____ fuel oil suction	Yellow	# ____ FUEL OIL
No. ____ fuel oil return	Yellow	# ____ FUEL OIL
Engine exhaust	Yellow	ENGINE EXHAUST
Lubricating oil	Yellow	LUB. OIL
Hydraulic oil	Yellow	HYDRAULIC OIL
Gasoline	Yellow	GASOLINE

Contents	Background colour marking	Legend
** Add design temperature		
++ Add design temperature and pressure		
Natural gas	to Codes	
Propane	to Codes	
Gas regulator vents	to Codes	
Distilled water	Green	DISTILL. WTR
Demineralized water	Green	DEMIN. WATER
Chlorine	Yellow	CHLORINE
Nitrogen	Yellow	NITROGEN
Oxygen	Yellow	OXYGEN
Compressed air (<700kPa)	Green	COMP. AIR ____ kPa
Compressed air (>700kPa)	Yellow	COMP. AIR ____ kPa
Vacuum	Green	VACUUM
Fire protection water	Red	FIRE PROT. WTR
Sprinklers	Red	SPRINKLERS
Carbon dioxide	Red	CO2
Instrument air	Green	INSTRUMENT AIR
Control air tubing	To Section 25 05 54 – EMCS: Identification	
Conduit for low voltage control wiring	To Section 25 05 54 – EMCS: Identification	
Medical Gases	To Code	

## 2.6 IDENTIFICATION DUCTWORK SYSTEMS

- .1 50 mm high stencilled letters and directional arrows 150 mm long x 50 mm high.
- .2 Colours: Black, or co-ordinated with base colour to ensure strong contrast.
- .3 Identify system : e.g. Supply AHU-1,Exhaust F-7.

## 2.7 VALVES, CONTROLLERS

- .1 Brass tags 12 mm diameter with stamped identification data filled with black paint.
- .2 Include flow diagrams for each system, of approved size, showing charts and schedules with identification of each tagged item, valve type, service, function, normal position, location of tagged item.

## 2.8 CONTROLS COMPONENTS IDENTIFICATION

- .1 Identify all systems, equipment, components, controls, sensors with system nameplates specified in section 25 05 54 – EMCS: Identification. If no EMCS included in project, identification as per this section.
- .2 Inscriptions to include function and (where appropriate) fail-safe position, component ID name.

---

## **2.9 LANGUAGE**

- .1 Identification to be in English.

## **PART 3 EXECUTION**

### **3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

### **3.2 TIMING**

- .1 Provide identification only after all painting specified in Section 09 91 23 - Interior Painting has been completed.

### **3.3 INSTALLATION**

- .1 Perform work in accordance with CAN/CGSB-24.3 except as specified otherwise.
- .2 Provide ULC and/or CSA registration plates as required by respective agency.

### **3.4 NAMEPLATES**

- .1 Locations:
  - .1 In conspicuous location to facilitate easy reading and identification from operating floor.
- .2 Standoffs:
  - .1 Provide for nameplates on hot and/or insulated surfaces.
- .3 Protection
  - .1 Do not paint, insulate or cover in any way.

### **3.5 LOCATION OF IDENTIFICATION ON PIPING AND DUCTWORK SYSTEMS**

- .1 On long straight runs in open areas in boiler rooms, equipment rooms, galleries, tunnels: At not more than 17 m intervals and more frequently if required to ensure that at least one is visible from any one viewpoint in operating areas and walking aisles.
- .2 Adjacent to each change in direction.
- .3 At least once in each small room through which piping or ductwork passes.
- .4 On both sides of visual obstruction or where run is difficult to follow.
- .5 On both sides of separations such as walls, floors, partitions.

- .6 Where system is installed in pipe chases, ceiling spaces, galleries, confined spaces, at entry and exit points, and at access openings.
- .7 At beginning and end points of each run and at each piece of equipment in run.
- .8 At point immediately upstream of major manually operated or automatically controlled valves, dampers, etc. Where this is not possible, place identification as close as possible, preferably on upstream side.
- .9 Identification to be easily and accurately readable from usual operating areas and from access points.
  - .1 Position of identification to be approximately at right angles to most convenient line of sight, considering operating positions, lighting conditions, risk of physical damage or injury and reduced visibility over time due to dust and dirt.

### **3.6 VALVES, CONTROLLERS**

- .1 Valves and operating controllers, except at plumbing fixtures, radiation, or where in plain sight of equipment they serve: Secure tags with non-ferrous chains or closed "S" hooks.
- .2 Install one copy of flow diagrams, valve schedules mounted in frame behind non-glare glass where directed by Owner's Representative. Provide one copy (reduced in size if required) in each operating and maintenance manual.
- .3 Number valves in each system consecutively.

### **3.7 CLEANING**

- .1 Proceed in accordance with Section 01 74 11 – Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, rubbish, tools and equipment.

**END OF SECTION**