



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Cape Beale Light Tower Refurbishmen	
Solicitation No. - N° de l'invitation F1700-150861/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client	Date 2015-11-05
GETS Reference No. - N° de référence de SEAG PW-\$PWY-031-7646	
File No. - N° de dossier PWY-5-38235 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-11-16	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (604) 666-8228 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Cape Beale Light Station - Bamfield, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Les documents français seront disponibles sur demande.

Amendment 002 has been raised to extend the closing date of this solicitation.

Extension of Time for Tenderers
Cape Beale Light Tower Refurbishment

DFO Pacific Region, Cape Beale, B.C.

Solicitation No: **F1700-150861/A**

Notice is hereby given that the time for reception of tenders previously due at 2:00 p.m. P.D.S.T. on 12 November 2015 is hereby extended to **2:00 p.m. P.D.S.T. on 16 November 2015.**

Amendment 002 has also been raised and to address questions.

Questions and Answers

1. Will the Contractor be permitted to remove the white day beacon strips to gain access to the area of Work?

A. Day beacon must remain in-service, day beacon slats/strips (painted 2x6 planks) can be removed if day beacon is temporarily replaced with similar white day beacon (for example white plastic used to encapsulate scaffolding/tower). If removed the day beacon slats/strips must be reinstalled by contractor at contractor's cost, must be replaced (and painted) if damaged during removal, and touch-up paint applied after reinstalled.
2. Confirm availability of accommodation at the Assistant/IRB residence at Lightkeepers Residence.

A. Yes, please see Amendment 1 on Buyandsell.gc.ca, page 26, Site Accommodations.
3. Confirm availability of on-site sanitary facilities.

A. Yes, if 'sanitary facilities' is bathroom (w/sink, toilet, bath/shower). Please see Amendment 1 on Buyandsell.gc.ca, page 26, Site Accommodations.
4. Confirm existing asbestos cladding panels are cementitious and approximately 40mm in thickness.

A. Existing asbestos panels are cementitious, but only ~9.5mm (3/8") thick.
5. Confirm hardcopy of bids to be sent to the address on page 2 of the Invitation to Tender document. Bids can then be revised via fax and all faxed amendments are only to include the adjustments to the previously submitted bid form, amendments are not to show final bid amounts.

A. Yes, hardcopy of bids are to be sent to the address on page 2 of the ITT document. You can use page 2 as your mailing label.

Yes, bids can be revised via fax amendments to include adjustments to the previously submitted bid form. Amendments can show final bid amounts but make sure it's indicated clearly. As per **SI05 REVISION OF BID**, a bid may be revised by letter or facsimile in accordance with GI10 of R2710T. The facsimile number for receipt of revisions is (604) 775-9381.

GI10 (2010-01-11) Revision of Bid

1. A bid submitted in accordance with these instructions may be revised by letter or facsimile provided the revision is received at the office designated for the receipt of bids, on or before the date and time set for the closing of the solicitation. The letter or facsimile shall be on the Bidder's letterhead or bear a signature that identifies the Bidder.
 2. A revision to a bid that includes unit prices must clearly identify the change(s) in the unit price(s) and the specific item(s) to which each change applies.
 3. A letter or facsimile submitted to confirm an earlier revision should be clearly identified as a confirmation.
 4. Failure to comply with any of the above provisions may result in the rejection of the non-compliant revision(s) only. The bid shall be evaluated based on the original bid submitted and all other compliant revision(s)
6. Does this project require performance and labour/material (50/50) bonds?
- A. Yes, as per GC9 Contract Security R2890D, on page 10 of the ITT solicitation document
7. Please clarify-are new steel components galvanized?
- A. New steel components, not galvanized except for the L76x64 horizontal shown on 2/S003 at Cape Beale and the L51x51 (Item #2) shown on Elevations on S003 at both sites. A325 bolts are also galvanized as indicated on the drawings.
8. Please confirm new metal cladding is to be painted as per your specifications?
- A. Painting of new metal cladding. New cladding (and all related exposed flashings, etc) to have factory/supplier prefinished paint, as per Section 07 42 13, subsections 2.2.1, 2.3.1, 2.3 .2, and 2.4.1 at the specifications.

All other terms and conditions remain unchanged.