



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Nootka Light Tower Refurbishment	
Solicitation No. - N° de l'invitation F1700-150765/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client	Date 2015-11-09
GETS Reference No. - N° de référence de SEAG PW-\$PWY-031-7645	
File No. - N° de dossier PWY-5-38234 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-11-16	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (604) 666-8228 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Nootka - Vancouver Island, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 003 has been raised and to address questions and to issue Addendum 1.

Questions and Answers

Q1. Is a license to Transport (LT) required for hazardous material transport by boat or helicopter from the stations?

A1. For transportation of hazardous materials by boat or helicopter, a License to Transport (LT) as issued by the BC Ministry of Environment is not required. However, any road transport of hazardous waste will require a LT. Also to note, the Transportation of Dangerous Goods regulations and Canada Shipping Act will still apply to any boat or helicopter transportation of hazardous materials.

Q2. May we sandblast to remove lead paint instead of chemical strip?

A2. An alternative method of removing the existing coatings (paint and lead paint) and preparing the steel (corrosion removal) to accept the specified coating (e.g. sandblasting, dry or wet method) can be proposed and would be acceptable to the owner providing contractor can sandblast safely (control dust, protect the environment, ensure worker and inspector safety), meet the surface preparation requirements, provide adequate containment, and adequately cleans-up at completion of work.

Q3. If by sandblasting it appears that this method is causing a concern with removing more steel material [steel material loss] than what might be removed by chemical means, will this be considered a change to site conditions and will the costs to replace such components be considered extra work?

A3. Generally, steel material loss not an anticipated issue but if during the blasting process components, other than the components already specified at drawings and specifications for replacement, were found to be 'thin' and replacement is required owner will consider as extra work.

Q4. If the owner decides that chemical removal would be better and requests the General Contractor to change work procedures to chemical removing then will the costs to do so ['extra costs'] be covered as a changed condition?

A4. : The General Contractor is required to meet the abatement and surface preparation requirements. If the General Contractor proposes alternative method of removing the existing coatings and owner (DFO and DFO consultant) officially agree (i.e. in-writing) and the surface preparation requirements are met then this item is a non- issue. If as work progresses the surface preparation requirements are not met and a change in method is required to meet the requirements the 'extra cost' would be by contractor. If as work progresses the surface preparation requirements are met but owner still decides that a change of method is required the 'extra cost' would be by owner. If 'extra cost' is by owner would have to look at credit for alternative method (sandblast) work not completed, mob-in/out costs for equipment, etc.

Q5. So if the General Contractor sandblasts to remove lead paint in order to provide a better quality of workmanship, then will the General Contractor be held harmless if any unforeseen damage occurs?

A5. The General Contractor and any hired or employed by the General Contractor are responsible for any damage caused by the General Contractor or those hired or employed by General Contractor. Unforeseen occurrences and conditions can arise in any project, if this does happen the owner, owner

Solicitation No. - N° de l'invitation
F1700-150765/A

Amd. No. - N° de la modif.
003

Buyer ID - Id de l'acheteur
PWY031

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-5-38234

CCC No./N° CCC - FMS No./N° VME

consultants and General Contractor will resolve (negotiate action, determine cost, who pays, etc.) when the unforeseen occurrence or condition arises.

Please see attached Addendum 1.

All other terms and conditions remain unchanged.

ADDENDUM



Project:	Nootka Light Tower Refurbishment	Addendum No.:	01
DFO Project No.:	F1700-150765	Date:	2015-November-06
WSP Project No.:	131-19104-11		
Distribution:	John Makkinga – DFO _____ Shaun Zealand – _____ Greg Ovstaas – GOAL Engineering _____		

GENERAL

*This Addendum forms part of the Contract Documents for **Nootka Light Tower Refurbishment** and amends the original drawings and Specifications. The following revisions supersede the information contained in the original drawings and Specifications issued to the extent referenced and shall become part thereof. No adjustment to the Contract Price will be considered or allowed due to the Contractor or to any sub-contractor or supplier not being familiar with this Addendum.*

Specifications

1. Section 07 42 13 Metal Wall Panels

- 1.1. Paragraph 2.1.1.3.1; **Revise** to read 'Profile to be a 300 mm wide by 40 mm deep' (Currently reads 'Profile to be a 300 mm wide by 25.4 mm deep').

End of Addendum