

Project: NATIONAL GALLERY OF CANADA
RETAIL STORE RENOVATION - CONSTRUCTION

Issued: November 5, 2015

Owner: NATIONAL GALLERY OF CANADA

GRC Project No.: 1915

Precedence: This addendum forms an integral part of the documents describing all aspects of the work and is to be read in conjunction therewith. However, if points arise which are at variance with previously issued information this Addendum shall take precedence.

Acknowledgement: Signify that you have received this Addendum by listing the Addendum number and date in the appropriate space on the Tender Form.

Object: The purpose of this addendum is:
.1 Clarify information provided in the specifications.
.2 Distribute new drawings and Schedules as applicable.

Distribution: (Tick all that apply)

Owner NGC Electrical
 Mechanical General Contractors

The following clarification relates to the specifications and drawings previously issued

1. Attachments:

.1 N/A.

2. Description:

Architectural - Drawings

.1 Item #1 – Reference: All Architectural Drawings.

.1 Clarification: Detail referencing in all drawings is to the DRG No. and not the SHEET No.

.2 Item #2 – Reference: SHEET A-11 – DOOR DETAILS

.1 Revise DRG No. from A-10 to A-11.

.3 Item #3 – Reference: SHEET A-12 – DOOR DETAILS

.1 Revise DRG No. from A-11 to A-12.

.4 Item #4 – Reference: SHEET A-13 – DOOR DETAILS

.1 Revise DRG No. from A-11 to A-13.

.5 Item #5 – Reference: SHEET A-03 – CONSTRUCTION PLAN

.1 New partitions between Future Tenant Space and adjacent spaces to have a 1hr. fire-

- resistance rating and be constructed to ULC W407. Include 38mm sound attenuation batts within stud cavity.
 - .2 Detail reference for DR01 at Electrical Closet to be revised from "MW/36" to "A/10".
 - .3 Detail reference for DR02 at Merchandise Storage to be revised from "MW/36" to "A/10".
 - .4 Detail reference for DR03 at Merchandise Storage to be revised from "A/10" to "A/11".
 - .5 Detail reference for DR04 at Admin Office to be revised from "A/10" to "A/11".
 - .6 Detail reference for DR05 at Change Room to be revised from "A/11" to "A/12".
 - .7 Detail reference for DR06 at Locker Room to be revised from "A/11" to "A/12".
 - .8 Detail reference for DR07 at Future Vacant Space to be revised from "A-11/M" to "A/13".
- .6 Item #6 – Reference: SHEET A-05 – REFLECTED CEILING PLAN**
- .1 Revise note to read "Recessed trough to be painted out dark grey – Finish J4. Refer to detail 1/A-09".
- .7 Item #7 – Reference: SHEET A-07 – FLOOR FINISHES PLAN**
- .1 Add symbol B1 for new baseboard in Change Room.
- .8 Item #8 – Reference: SHEET MW-03 – INTERIOR ELEVATIONS**
- .1 Detail reference "MW/04 Ceiling / track lighting detail 1" to be revised to "A/09" under Elevation C.
- .9 Item #9 – Reference: SHEET MW-06 – SHOPFRONT ELEVATIONS & DETAILS**
- .1 Detail reference for DR03 in 'Elevation C' and in 'Plan' to be revised from "M/37" to "A/11".
- .10 Item #10 – Reference: SHEET MW-07 – ELECTRICAL CUPBOARD AREA DETAILS**
- .1 Detail reference for DR01 in 'Plan' to be revised from "M/36" to "A/10".
- .11 Item #11 – Reference: SHEET MW-09 – REAR WALL FIXTURE LAYOUT**
- .1 Detail reference for DR02 in 'Rear Wall Fixture Layout – Elevation A' to be revised from "M/36" to "A/10".

Architectural - Specifications

- .1 Item #12 – Reference: Section 07 92 00 – Sealants.**
- .1 Add clause 2.3.4 "Joints in new architectural precast header: Tremco Spectrum 4-TS."
- .2 Item #13 – Reference: Section 09 21 99 – Partitions for Minor Works.**
- .1 Add clause 3.5.9 "Apply two layers of 13mm gypsum board to new partitions where honed concrete finish is to be applied."

.3 Item #14 – Section 03 45 00 – Architectural Precast Concrete.

.1 Add entire specification section 03 45 00 – Architectural Precast Concrete.

Prepared By:



Eric Laflamme
