



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving Public Works and Government**  
**Services Canada/Réception des soumissions**  
**Travaux publics et Services gouvernementaux**  
**Canada**  
**800 Burrard Street, Room 219**  
**800, rue Burrard, pièce 219**  
**Vancouver**  
**British Columbia**  
**V6Z 0B9**  
**Bid Fax: (604) 775-9381**

## **SOLICITATION AMENDMENT**

## **MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### **Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

|   |   |
|---|---|
| <b>Title - Sujet</b><br>Nootka Light Tower Refurbishment  |   |
| <b>Solicitation No. - N° de l'invitation</b><br>F1700-150765/A  | <b>Amendment No. - N° modif.</b><br>004                                   |
| <b>Client Reference No. - N° de référence du client</b>   | <b>Date</b><br>2015-11-12   |
| <b>GETS Reference No. - N° de référence de SEAG</b><br>PW-\$PWY-031-7645  |   |
| <b>File No. - N° de dossier</b><br>PWY-5-38234 (031)  | <b>CCC No./N° CCC - FMS No./N° VME</b>                                    |
| <b>Solicitation Closes - L'invitation prend fin</b><br><b>at - à 02:00 PM</b><br><b>on - le 2015-11-16</b>  | <b>Time Zone</b><br><b>Fuseau horaire</b><br>Pacific Standard Time<br>PST |
| <b>F.O.B. - F.A.B.</b><br><b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/> |   |
| <b>Address Enquiries to: - Adresser toutes questions à:</b><br>Leung, Janie   | <b>Buyer Id - Id de l'acheteur</b><br>pwy031                              |
| <b>Telephone No. - N° de téléphone</b><br>(604) 666-8228 ( )  | <b>FAX No. - N° de FAX</b><br>(604) 775-6633                              |
| <b>Destination - of Goods, Services, and Construction:</b><br><b>Destination - des biens, services et construction:</b><br>DFO - Nootka - Vancouver Island, BC              |   |

**Instructions: See Herein**

**Instructions: Voir aux présentes**

|  |  |
|--|--|
| <b>Delivery Required - Livraison exigée</b>  | <b>Delivery Offered - Livraison proposée</b> |
| <b>Vendor/Firm Name and Address</b><br><b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>   |  |
| <b>Telephone No. - N° de téléphone</b><br><b>Facsimile No. - N° de télécopieur</b>   |  |
| <b>Name and title of person authorized to sign on behalf of Vendor/Firm</b><br><b>(type or print)</b><br><b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b><br><b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b> |  |
| <b>Signature</b>   | <b>Date</b>                                  |

Solicitation No. - N° de l'invitation  
F1700-150765/A

Amd. No. - N° de la modif.  
004

Buyer ID - Id de l'acheteur  
PWY031

Client Ref. No. - N° de réf. du client

File No. - N° du dossier  
PWY-5-38234

CCC No./N° CCC - FMS No./N° VME

---

Amendment 004 has been raised and to address questions and to issue Addendum 2.

### **Questions and Answers**

Q1. Our window suppliers have brought to our attention the project specs for window NAFS and PG Ratings do not coincide with each other. I've attached a chart with common window types and their associated ratings. Please review this information and advise whether the spec needs to be updated so that ratings coincide with each other.

A1. Please use the # 2 Window in the Table. This is a vertical slider (VS) with positive and negative design pressure of 3360 and -3360 Pa. Please see attached addendum.

Q2. Our window suppliers have brought to our attention the specified vertical sliders are not available with aluminum frames. Please advise whether vinyl windows are acceptable or if aluminum is required can an awning/casement style be used.

A2. Vinyl was to be specified and is acceptable, Aluminum is not acceptable. Please see attached addendum.

Q3. Please advise the window size for the new storm door as referenced in specification 07 42 13 .5.2.

A3. The storm door is specified to fit existing opening and the window should be about 2/3's size of door such as at Cape Beale.

Q4. Per Amendment 002 and Specification Section 07 42 13 the roofing and cladding are to be a Coast Guard Red – PVDF and Coast Guard White – PVDF. These colours in a PVDF finish is a custom order which have a 3 – 4 month. This doesn't allow for the project to be completed by March 6, 2016 per Section 01 11 00, 1.3.

Can the completion date be extended to accommodate the specified finish?

Will SMP (this finish is readily available in Coast Guard Red & Coast Guard White) be acceptable?

A4. The cladding coating is specified to be a Pre-painted Polyvinylidene Fluoride System. A pre-approved system is Valspar Flurothane Coastal with coating thickness as defined by the manufacturer. Colours to be as specified. We understand that delivery on this product may be 12 to 16 weeks and alternates will be considered. Please see attached addendum.

Please see attached Addendum 2.

**All other terms and conditions remain unchanged.**

# ADDENDUM



|                         |   |                      |                  |
|-------------------------|---|----------------------|------------------|
| <b>Project:</b>         | Nootka Light Tower Refurbishment  | <b>Addendum No.:</b> | 02               |
| <b>DFO Project No.:</b> | F1700-150765  | <b>Date:</b>         | 2015-November-12 |
| <b>WSP Project No.:</b> | 131-19104-11  |                      |                  |
| <b>Distribution:</b>    | John Makkinga – DFO – _____<br>Shaun Zealand – DFO – _____<br>Greg Ovstaas – GOAL Engineering – _____ |                      |                  |

## GENERAL

*This Addendum forms part of the Contract Documents for **Nootka Light Tower Refurbishment** and amends the original drawings and Specifications. The following revisions supersede the information contained in the original drawings and Specifications issued to the extent referenced and shall become part thereof. No adjustment to the Contract Price will be considered or allowed due to the Contractor or to any sub-contractor or supplier not being familiar with this Addendum.*

## Specifications

### 1. Section 07 42 13 Metal Wall Panels

- 1.1. Paragraph 2.1.1.5.1; **Revise** to read 'To be Vertical sliders (approximately 550 mm x 1010 mm) meeting the requirements of NAFS Class R – PG2400 metric VS. Windows shall fit in rough opening left by two widths of the steel cladding approximately 1025 in length. Submit shop drawings to show window and flashing installation'.

(Currently reads 'To be Vertical sliders (approximately 550 mm x 1010 mm) meeting the requirements of NAFS Class AW – PG3600 metric VS. Windows shall fit in rough opening left by two widths of the steel cladding approximately 1025 in length. Submit shop drawings to show window and flashing installation')

- 1.2. **Clarification;** the window components including frame and sash shall be vinyl.
- 1.3. **Clarification;** the storm door window shall be sized to be approximately 2/3 the height of the door.
- 1.4. **Clarification;** the cladding coating is specified to be a Pre-painted Polyvinylidene Fluoride System. A pre-approved system is Valspar Flurothane Coastal with coating thickness as defined by the manufacturer. Colours to be as specified. We understand that delivery on this product may be 12 to 16 weeks and alternates will be considered.

**End of Addendum**