



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Cape Beale Light Tower Refurbishmen	
Solicitation No. - N° de l'invitation F1700-150861/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client	Date 2015-11-12
GETS Reference No. - N° de référence de SEAG PW-\$PWY-031-7646	
File No. - N° de dossier PWY-5-38235 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-11-16	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (604) 666-8228 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Cape Beale Light Station - Bamfield, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1700-150861/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
PWY031

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-5-38234

CCC No./N° CCC - FMS No./N° VME

Amendment 004 has been raised and to address questions and to issue Addendum 2.

Questions and Answers

Q1. Per Amendment 002 and Specification Section 07 42 13 the roofing and cladding are to be a Coast Guard Red – PVDF and Coast Guard White – PVDF. These colours in a PVDF finish is a custom order which have a 3 – 4 month. This doesn't allow for the project to be completed by March 6, 2016 per Section 01 11 00, 1.3.

Can the completion date be extended to accommodate the specified finish?

Will SMP (this finish is readily available in Coast Guard Red & Coast Guard White) be acceptable?

A1. The cladding coating is specified to be a Pre-painted Polyvinylidene Fluoride System. A pre-approved system is Valspar Flurothane Coastal with coating thickness as defined by the manufacturer. Colours to be as specified. We understand that delivery on this product may be 12 to 16 weeks and alternates will be considered. Please see attached addendum.

Please see attached Addendum 2.

All other terms and conditions remain unchanged.

ADDENDUM



Project:	Cape Beale Light Tower Refurbishment	Addendum No.:	02
DFO Project No.:	F1700-150861	Date:	2015-November-12
WSP Project No.:	131-19104-11		
Distribution:	John Makkinga – DFO – _____ Shaun Zealand – DFO – _____ Greg Ovstaas – GOAL Engineering – _____		

GENERAL

*This Addendum forms part of the Contract Documents for **Cape Beale Light Tower Refurbishment** and amends the original drawings and Specifications. The following revisions supersede the information contained in the original drawings and Specifications issued to the extent referenced and shall become part thereof. No adjustment to the Contract Price will be considered or allowed due to the Contractor or to any sub-contractor or supplier not being familiar with this Addendum.*

Specifications

1. Section 07 42 13 Metal Wall Panels

- 1.1. **Clarification;** the cladding coating is specified to be a Pre-painted Polyvinylidene Flouride System. A pre-approved system is Valspar Flurothane Coastal with coating thickness as defined by the manufacturer. Colours to be as specified. We understand that delivery on this product may be 12 to 16 weeks and alternates will be considered.

End of Addendum