



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Electrical Supplies	
Solicitation No. - N° de l'invitation W2037-160055/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client W2037-160055	Date 2015-11-12
GETS Reference No. - N° de référence de SEAG PW-\$PWB-101-3728	
File No. - N° de dossier PWB-5-38096 (101)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-12-15	
Time Zone Fuseau horaire Atlantic Standard Time AST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lomax, Sandra	Buyer Id - Id de l'acheteur pwb101
Telephone No. - N° de téléphone (506) 636-4362 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Solicitation Amendment No. One (1) is raised to include the following Addendum No. One (1).

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

QUESTION AND ANSWERS

Question

1. Items 1 through 5 and 7 through 17, your client is asking for 'T90' wire, would 'RW90' be a sufficient substitute?

Answer

1. RW90 is acceptable

Question

2. Items 1 through 17, your client is asking for a total of 750m, this wire, whether it be T90, RW90, or Bare Copper, typically comes on 300M reels, would your client take 900M total or only 600M?

Answer

2. As per the Basis of Payment "In situations where a minimum quantity is required (e.g. wire in 300M rolls), the bidder must identify the least amount that shall be provided in order to deliver the quantity requested." 900M is acceptable

Question

3. Items 18 through 25, the TEW, typically comes in 150M or 300M coils, would your client take 900M of each instead of 1000M or 500M?

Answer

3. See answer to question 4. 600M and 1200M are acceptable.

Question

4. Items 72 and 74, does client require the E-Stop/ Enclosure to be Nema or IES rated?

Answer

4. Nema is acceptable

Question

5. Items 86 through 91, your client is asking for Square D, will they accept Cutler Hammer?

Answer

5. Square D is necessary

Question

6. Items 92 through 94, your client is asking for Leviton, will they accept Hubbell?

Answer

6. Yes

Question

7. Items 95,97,99,100, and 101, your client is asking for Square D, will they accept Cutler Hammer and/or Hubbell?

Answer

7. Square D is necessary

Solicitation No. - N° de l'invitation
W2037-160055/A
Client Ref. No. - N° de réf. du client
W2037-160055

Amd. No. - N° de la modif.
001
File No. - N° du dossier
PWB-5-38096

Buyer ID - Id de l'acheteur
pwb101
CCC No./N° CCC - FMS No./N° VME

Question

8. Item 102, what is the manufacturer and make of the DPDT Thermostat Modulating Ability?

Answer

8. HONEYWELL Line Volt Mechanical Tstat, 120 to 240VAC part # T6051A1016

Question

9. Item 108, is the transformer to have copper or aluminum windings?

Answer

9. Copper