

Solicitation No. - N° de l'invitation

Amd. No. - N° de la modif.

Buyer ID - Id de l'acheteur

EA003-161421/A

01

pwd005

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME

R.068178.001

PWD-5-38153

ADDENDUM NO. 1

THE FOLLOWING AMENDMENT TO THE BID DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE ADDENDUM SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

DRAWINGS:

1. On drawing A01, revise Demolition note "17" to read:

"REMOVE EXISTING CARPET IN THESE ROOMS AND DISPOSE OF OFF SITE. REMOVE EXISTING GLUE AND OTHER FOREIGN MATTER FROM THE CONCRETE FLOOR SLAB AND DISPOSE OF OFF SITE. PREPARE FLOOR SLAB FOR INSTALLATION OF NEW FLOORING"
2. Delete drawing numbered A05 and replace with revised drawing A05, attached herewith.
3. Revise the single glazing of G18-204 and G-18-205 as indicated and reference on Drawing A02 and A05 to single panes of laminated glass using polyvinyl butyral (PVB) plastic interlayer between 2 layers 6mm safety glass. Maintain the post-applied patterned frosted surface film details.

By submission of its bid, the Bidder confirms that it has read and understands the requirements expressed in all addenda & has included all costs of these requirements in its Total Bid Amount.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.