



SEQUENCE OF OPERATION:

1. WHEN THE TIMER FOR THE SMUDGING ROOM FAN IS TURNED ON, THE EXHAUST FAN STARTS AND THE MOTORIZED DAMPER CLOSES.
2. TIMER SHALL BE ADJUSTABLE UP TO 2 HRS.

6
—

CONTROLS SCHEMATIC — CULTURAL CENTRE 210
VENTILATION

SCALE : N.T.S.

Public Works and Government Services Canada Travaux publics et Services gouvernementaux Canada	Drawing title MECHANICAL CONTROLS		designed CST	conçu CST	date NOV.05,2015	
	project HALIFAX — DARTMOUTH COMMUNITY CORRECTIONAL CENTRE DARTMOUTH, N.S.		drawn KRG	dessiné KRG	date NOV.05,2015	
		approved TEW	approuvé TEW	date NOV.05,2015		
		Tender PWGSC Project Manager				Soumission Administrateur de projets TPSGC
		project number R.035143.001	no. du projet R.035143.001	drawing no. V501	no. du dessin V501	