

HEATING COIL SCHEDULE

DESIGNATION	SERVICE	AIRFLOW (l/s)	FLUID FLOW (l/s)	EWT (C°)	LWT (C°)	EAT (C°)	LAT (C°)	HEATING CAPACITY (kW)	MAX FLUID PD (kPa)	MAX AIR PD (Pa)	COMMENTS
HC-1	HRV-1	956	0.28	82	60	-1	21	25.6	29.9	13	-
HC-2	HRV-2	151	0.05	82	60	-1	21	4	29.9	13	-
HC-3	HRV-3	151	0.05	82	60	-1	21	4	29.9	13	-
HC-4	HRV-4	151	0.05	82	60	-1	21	4	29.9	13	-
HC-5	HRV-5	151	0.05	82	60	-1	21	4	29.9	13	-
HC-6	HRV-6	151	0.05	82	60	-1	21	4	29.9	13	-

NOTE: COORDINATE REQUIRED DUCT TRANSITIONS WITH DUCTWORK INSTALLER AT SHOP DRAWING PHASE. ACCEPTABLE MANUFACTURERS: MADOK, ROSEMEX, TRANE, HEATCRAFT, YORK, MCQUAY, CARRIER OR APPROVED EQUIVALENT.

 Public Works and Government Services Canada	Travaux publics et Services gouvernementaux Canada	project	HALIFAX-DARTMOUTH COMMUNITY CORRECTIONAL CENTRE DARTMOUTH, N.S.	project	Drawing title	Titre du dessin	designed	conçu	date
		Tender		Soumission	R.035143.001	MECHANICAL HEATING SCHEDULES	CST	date	NOV.06,2015
PWGSC Project Manager		Administrateur de projets TPSGC		project number		no. du projet		drawing no.	no. du dessin
				R.035143.001				H601	