



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency
National Contracting Services
111, Water Street East
Cornwall ON K6H 6S3
ATTN: Céline Morin**

QUESTIONS AND ANSWERS NO 3

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission à : l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency
National Contracting Services
111 Water Street East
Cornwall ON K6H 6S3**

Title-Sujet Atwater Pedestrian Bridge Rehabilitation, Lachine Canal		Date November 16, 2015
Solicitation No. - No. de l'invitation 5P300-15-5461	Client Ref. No. - No. de réf du client.	
GETS Reference No. - No de reference de SEAG 5P300-15-5461		
Solicitation Closes L'invitation prend fin - REVISED at - à 02:00 PM on - le 2015-11-18	Time Zone Fuseau horaire - Eastern Standard Time (EST)	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: x Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Céline Morin (celine.morin@pc.gc.ca)		
Telephone No. - No de téléphone 613-938-5940	Fax No. - No de FAX:	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur : Telephone No. - No de téléphone: _____ Facsimile No. - N° de télécopieur: _____		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur _____ Name / Nom Title / Titre _____ Signature Date		



IS 5P300-15-5461
Atwater Pedestrian Bridge Rehabilitation, Lachine Canal

QUESTIONS AND ANSWERS NO. 3

- 1) On the Atwater Market side, there are railroad tracks. Could you tell us if these are CN tracks and whether there are any restrictions for our work?

Yes, CN tracks pass on the north shore of the Atwater pedestrian bridge.

The Contractor must provide to CN plans or sketches of any temporary or permanent facilities that will be located near the tracks, such as temporary fences, barriers, equipment, platforms, permanent signage, etc.

No facilities, machinery or equipment may be positioned less than 8.5' from the closest rail.

The Contractor must submit for approval their plan or sketch for site signage and fences so that CN may verify that the 8.5 feet restriction is being respected.

- 2) Will a CN signalman be on site because there will be equipment being used?

When a train passes, there will be a CN signalman on site.

- 3) Are we expected to pay CN fees for a signalman?

No, agreements exist between CN and Parks Canada.

- 4) Do you know at what frequency trains go through?

Normal rail traffic has one train passing between 7:00 a.m. and 3:00 p.m. on Monday, Wednesday and Friday.

The Contractor must follow up with CN to obtain and confirm the information on the restrictions and prerequisites before beginning any work.