



NOTE:
LOCATE CONTROL VALVE AND TRIM ADJACENT TO HEATING COIL UNIT. ENSURE VALVE ASSEMBLY IS ACCESSIBLE. 3-WAY VALVE ONLY REQUIRED AT HRV-1 HEATING COIL – ALL OTHER HEATING COILS TO BE 2-WAY CONTROL VALVES.



DETAIL — HEATING COIL PIPING (TYP.)

SCALE : N.T.S.

 <div>Public Works and Government Services Canada</div>	<div>Travaux publics et Services gouvernementaux Canada</div>	project <div>HALIFAX — DARTMOUTH COMMUNITY CORRECTIONAL CENTRE DARTMOUTH, N.S.</div>	projet <div>HALIFAX — DARTMOUTH COMMUNITY CORRECTIONAL CENTRE DARTMOUTH, N.S.</div>	Drawing title <div>MECHANICAL HEATING DETAILS</div>	Titre du dessin <div>MECHANICAL HEATING DETAILS</div>	designed CST	conçu CST	date NOV.13,2015	
						drawn KRG	dessiné KRG	date NOV.13,2015	
						approved TEW	approuvé TEW	date NOV.13,2015	
						project number R.035143.001		no. du projet R.035143.001	
Tender		Soumission		PWGSC Project Manager		Administrateur de projets TPSGC			