



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave. Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6  
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6

<b>Title - Sujet</b> BNP Wastewater System Upgrade	
<b>Solicitation No. - N° de l'invitation</b> E0209-161419/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b> Parks-E0209-161419	<b>Date</b> 2015-11-17
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-201-10619	
<b>File No. - N° de dossier</b> PWU-5-38238 (201)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2015-12-03</b>	
<b>Time Zone</b> Fuseau horaire Mountain Standard Time MST	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ho (RPC), Hector	<b>Buyer Id - Id de l'acheteur</b> pww201
<b>Telephone No. - N° de téléphone</b> (780) 901-0989 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
E0209-161419/A  
Client Ref. No. - N° de réf. du client  
E0209-161419

Amd. No. - N° de la modif.  
001  
File No. - N° du dossier  
PWU-5-38238

Buyer ID - Id de l'acheteur  
pwu201  
CCC No./N° CCC - FMS No./N° VME

---

**This Amendment has been raised to answer the following questions and to Include Addendum #001 as part of the Term of Reference.**

**Question 1:**

Are these (Westcon Tanks) the recommended tanks by the project manager or Parks Canada and would this not disenfranchise/disadvantage other manufactures like to the General Contractors bidding on the job as we would seem not to be a Parks Canada's/Project Manager's preferred supplier or recommended solution? Would it be disadvantageous on your end to just list the required minimum and maximum capacities of the tanks and possible dimensions without referring to or promoting a specific supplier?

**Answer 1:**

There is no preference for the listed septic tank; it was provided as a design basis to demonstrate to bidders the type of tank required (pre-cast septic tank). Bidders are free to provide alternates so long as sizing matches minimum volumes outlined on drawings.

**Question 2:**

Is there a reason why Westcon was specked as the supplier and how can we get our tanks specked for Parks Canada jobs as we make equivalent products.

**Answer 2:**

See Answer 1.

**Question 3:**

Item 3.12 Septic Tank (1500 gallons) and Item 4.9 Septic Tank (2000 gallons) are the only two requested sizes for the septic tanks whereas in the General Notes Sheet C005 of the drawings, Table 1 and Table 2 show some of the sites would require tanks greater than requested on the Unit Price Table?

**Answer 3:**

Bidders are required to provide unit pricing for larger tanks as part of the bid form. Item 3.12 and Item 4.9 only include the two sizes to facilitate Bid evaluation.

**Question 4:**

[Provide] dimensions of the following items [Concrete Valve Box] from the Unit Price Table?

**Answer 4:**

There is no concrete valve box specified. Design basis was Brooks Style Valve Box, approximately 545 mm x 370 mm (outside dimensions).

Solicitation No. - N° de l'invitation  
E0209-161419/A  
Client Ref. No. - N° de réf. du client  
E0209-161419

Amd. No. - N° de la modif.  
001  
File No. - N° du dossier  
PWU-5-38238

Buyer ID - Id de l'acheteur  
pwu201  
CCC No./N° CCC - FMS No./N° VME

<b>Project Title</b>	<b>Addendum No.:</b>
Septic System Upgrades	1
<b>Project Location:</b>	<b>Project Number:</b>
Banff National Park, Alberta	R.077777.001
<b>Consultant's Name:</b>	<b>Date:</b>
	November 17, 2015

**The following changes on the bid documents are effective immediately.  
This addendum will form part of the contract documents.**

**Drawings**

No changes.

**Specifications**

- 1. Section 01 11 00 – Summary of Work:** Delete Article 1.6.2 entirely and replace with the following:
  - .2 Construction schedule is to be as follows:
    - .1 Two Jack Main Campground:
      - .1 April 1 to June 21, and September 8 to completion in 2016.
      - .2 Absolutely no work is to take place between June 22 to September 7, 2016; Contractor must demobilize off site. All 16 systems must be in full operation using either new or old system; areas must also be left clean and tidy. No equipment, supplies or waste is to be stored on site during this time.
    - .2 East Gate: June 22 to completion in 2016. This site is priority once contractor has demobilized from Two Jack Main
    - .3 Cascade Pond DUA: Complete after East Gate site, but prior to September 8, 2016.”
- 2. Section 01 11 00 – Summary of Work:** Add new Article 1.6.5.3.1 as follows:
  - .1 All pumping required at East Gate during construction shall be the responsibility of the Contractor.”
- 3. Section 02 41 13 – Selective Site Demolition:** Add new Article 1.3.2.1.3 as follows:
  - .3 There is an abandoned pit privy pit adjacent to Cascade Pond leach pit/septic field. This shall be reclaimed during construction at the site.”

**All other Terms and Conditions remain unchanged**