



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des
soumissions/Travaux publics et Services
gouvernementaux Canada
The Cambridge Building
3 Queen Street/3, rue Queen
Charlottetown
Prince Edward Island
C1A 4A2

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Authority, Crystal Bysterveldt, either by facsimile or by e-mail at:
crystal.bysterveldt@pwgsc.gc.ca

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada
The Cambridge Building
3 Queen Street/3 rue, Queen
PO Box 1268/CP 1268
Charlottetown
Prince Ed
C1A 4A2

Title - Sujet Steel Repairs Northport/Naufrage PE	
Solicitation No. - N° de l'invitation ED001-161529/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client R.076459.001	Date 2015-11-18
GETS Reference No. - N° de référence de SEAG PW-\$PWC-024-3735	
File No. - N° de dossier PWC-5-38119 (024)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-11-25	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Bysterveldt, Crystal	Buyer Id - Id de l'acheteur pwc024
Telephone No. - N° de téléphone (902) 940-7122 ()	FAX No. - N° de FAX (902) 566-7514
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Addendum is raised to provide the following answers to questions provided by bidders.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

ANSWERS TO QUESTIONS

1. **QUESTION**

Given that the SSP repair length is 154 meters will the quantities on the unit bid sheet be adjusted to reflect that?

ANSWER

The unit price table will remained unchanged.

2. **QUESTION**

There seems to be some information missing on the steel sizes shown for the Prefabricated Shear Stud Strips. The diameter of the 60mm shear studs is not shown along with the width of the 10mm thick plates.

ANSWER

The plate is 150mm wide and the studs are 13mm diameter.