


- GENERAL NOTES:
1. RE-USE EXISTING CIRCUITRY FOR NEW FUME HOODS (REPLACING EXISTING).
 2. WHERE EXISTING FUME HOODS ARE REPLACED WITH NEW, FUME HOOD RECEPTACLES ARE ALSO TO BE REPLACED WITH NEW. NEW RECEPTACLES SHALL MATCH EXISTING IN A LIKE-FOR-LIKE FASHION. RE-USE EXISTING CIRCUITRY.
 3. WHERE INDICATED FOR A NEW VAV BOX TO BE INSTALLED, PROVIDE AN ADDITIONAL 120V CIRCUIT IN CEILING JUNCTION BOX FOR USE BY MECHANICAL CONTROLS TRANSFORMERS.
 4. ELECTRICAL CONTRACTOR SHALL PROVIDE NEW UPDATED PANEL DIRECTORIES FOR EXISTING PANELS THAT HAVE BEEN MODIFIED WITH THE SCORE OF WORK.


THIRD FLOOR NEW ELECTRICAL 1 E306

SCALE: 1:50
0m 1m 2m 3m 4m 5m



M&R ENGINEERING LIMITED
5531 Cornwallis St. Halifax, NS, B3K 1B3
Tel: (902) 422-7393, Fax: (902) 423-4945
Website: www.mreng.ca

GENERAL NOTES :
DO NOT SCALE THIS DRAWING FOR CONSTRUCTION PURPOSES. USE FIGURED DIMENSIONS AS NOTED.
THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH SPECIFICATIONS AND GENERAL CONTRACTUAL CONDITIONS.
ALL DIMENSIONS AND CONDITIONS ARE TO BE VERIFIED ON SITE. ALL DISCREPANCIES ARE TO BE REPORTED TO THE DEPARTMENTAL REPRESENTATIVE AND AGREED UPON WITH THEM IN WRITING BEFORE PROCEEDING WITH WORKS.
INFORMATION ON THESE DRAWINGS IS TO BE USED FOR THIS PROJECT ONLY AND SHALL NOT BE USED FOR ANY OTHER PURPOSE.



3	ISSUED FOR TENDER	OCT 28 2015
2	99% REVIEW	SEP 11 2015
1	66% REVIEW	JUNE 30 2015
revisions		date

project
AFC KENTVILLE RESEARCH CENTRE LABORATORY BLOCK-C CONTROLS SYSTEM UPGRADE KENTVILLE, N.S.

drawing no. NEW THIRD FLOOR ELECTRICAL LAYOUT

designed TML
date JULY 2015
drawn JCN
date JULY 2015
approved
date
Tender
PWGSC Project Manager Administrateur de projets TPWGC
project number no. du projet
R.074306.001
drawing no. no. du dessin
E306