



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
B3J 1T3
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
B3J 3C9
Nova Scot

Title - Sujet Portable Steam Boiler	
Solicitation No. - N° de l'invitation W0100-16I023/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client W0100-16-I023	Date 2015-11-23
GETS Reference No. - N° de référence de SEAG PW-\$HAL-309-9635	
File No. - N° de dossier HAL-5-75101 (309)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-12-01	
Time Zone Fuseau horaire Atlantic Standard Time AST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: MacNeil, Blaine A.	Buyer Id - Id de l'acheteur hal309
Telephone No. - N° de téléphone (902) 496-5180 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment #1

Bidder Q & A's:

1. Do you want two feedwater pumps, one would be a backup.
One pump is all that's needed.
2. Do you want a feedwater tank pre heater. (sometimes when DND rents boiler to heat ships there is no condensate return).
Good point, this should be added to the specification.

Action: in the RFP at Annex A, Statement of Requirement, Containerized Boiler Room,

Delete: 1 b) "Condensate return tank with makeup water control;"

Insert: 1 b) "Condensate return tank with makeup water control and Pre Heater;"

3. Do you want a guarded plant panel.
No, Boiler will be monitored
4. What would the inlet gas pressure be.
20 PSI
5. All the boiler manufactures are saying 10/12 week delivery on boilers.
Understood, this was expected.
6. The permanent location of the unit, due to weather conditions and climate can impact materials used and construction methods.
Location is in the Dockyard Halifax
7. If the unit will be permanently anchored to a concrete slab or flooring of some kind. This will affect the type of connections to external fuel sources to conform to codes and safety regulations.
Boiler should be anchored to trailer by some means.
8. With units such as this, the regulations we must follow are provincially based. Should this unit conform to its deemed location only, or is it required to conform to all provincial standards. This is to foresee if the unit could be shipped to another province and still be in code to the new location.
Boiler will be used in NS only.
9. In the solicitation documents, there is no mention of independent standby heating. Would this be required?
No
10. Annex A has a statement of requirements that lists an air compressor, however, there are no other details regarding this equipment. Can we get clarification on its purpose, and capacity required?

Only needed for the use of boiler, if no air is required by the unit then it is not required.

11. Could you please provide copies of water analysis and/or range of raw water quality that is to be treated by the water conditioning system that is to be provide with Boiler package under this RFP.

We are using city water, <http://www.halifax.ca/hrwc/documents/Pockwock-LakeMajor2013-2014-FINAL-KM.pdf> Use the pockwock column.

12. Do you need that all of the equipment (boiler/burner/tanks/container) to be new or you will accept used and/or refurbished equipment?

No, we require new equipment

13. Do you know what will be the percentage of makeup water? (or percentage of condensate return?)

This will vary with what we hook up to. Expect between 5 to 60%.

14. Do you have the feedwater conditions to correctly size the water softeners and chemicals?

The water used is the same as domestic water from Halifax Regional Municipality. The makeup conditions are 5 to 60%

15. Do you have the natural gas pressure available at the container inlet?

20 PSI

All other terms and conditions remain unchanged.