

**Common Work Results - Electrical**

**Page 1**

- |    |  |    |  |
|----|--|----|--|
| 1. | <u>General</u>                               | 1. | This Section describes the requirements for the supply and installation of new conduit sleeves.  |
| 2. | <u>Related Work</u>                          | .1 | See <b>Section 31 11 00</b> , Site Work Demolition and Removal for related requirements regarding removal of existing electrical work (poles, conduits, wiring, etc.). |
| 3. | <u>Codes and Standards</u>                   | .1 | Do complete installation in accordance with CSA C22.1-02 except where specified otherwise.   |
|    |  | .2 | Do overhead and underground systems in accordance with CSA C22.3 No. 1-M1979 except where specified otherwise.   |
|    |  | .3 | Abbreviations for electrical terms: to CSA Z85-1983.   |
| 4. | <u>Measurement for Payment</u>               | .1 | Electrical work covered under this section and shown on plan will not be measured for payment and is considered incidental to the work.                                |
| 6. | <u>Removal of Existing Electrical System</u> | .1 | See <b>Section 31 11 00</b> for requirements.  |
| 7. | <u>Conduit Installation</u>                  | .1 | Install conduit and sleeves prior to pouring of concrete. Sleeves through concrete: sized for free passage of conduit, and flush with face of pile cap and deck.       |
| 8. | <u>Conduit</u>                               | .1 | Rigid PVC conduit to CSA C22.2 No. 211.2 and C22.2 No. 211.0.  |