


**M&R ENGINEERING LIMITED**  
5531 Cornwallis St. Halifax, NS, B3K 1B3  
Tel: (902) 422-7393, Fax: (902) 423-4945  
Website: www.mreng.ca

GENERAL NOTES :  
DO NOT SCALE THIS DRAWING FOR CONSTRUCTION PURPOSES. USE FIGURED DIMENSIONS AS NOTED.  
THESE DRAWINGS ARE TO BE READ IN CONJUNCTION WITH SPECIFICATIONS AND GENERAL CONTRACTUAL CONDITIONS.  
ALL DIMENSIONS AND CONDITIONS ARE TO BE VERIFIED ON SITE. ALL DISCREPANCIES ARE TO BE REPORTED TO THE DEPARTMENTAL REPRESENTATIVE AND AGREED UPON WITH THEM IN WRITING BEFORE PROCEEDING WITH WORKS.  
INFORMATION ON THESE DRAWINGS IS TO BE USED FOR THIS PROJECT ONLY AND SHALL NOT BE USED FOR ANY OTHER PURPOSE.




3	ISSUED FOR TENDER	OCT 28 2015
2	99% REVIEW	SEP 11 2015
1	66% REVIEW	JUN 30 2015
revisions		date

project  
**A AFC KENTVILLE RESEARCH CENTRE LABORATORY BLOCK-C CONTROLS SYSTEM UPGRADE KENTVILLE, N.S.**

drawing  
**SECOND FLOOR VENTILATION: NEW LAYOUT**

designed PFH  
date JULY 2015  
drawn CAB  
date JULY 2015  
approved  
date  
Tender  
PWGSC Project Manager / Administrateur de projets TPWGC  
project number  
**R.074306.001**  
drawing no.  
**H304**



SECOND FLOOR VENTILATION: NEW LAYOUT

SCALE: 1:50  
0m 1m 2m 3m 4m 5m

LEGEND:	
550# HOT SUPPLY FROM BELOW	500# COLD SUPPLY UP
600# COLD SUPPLY FROM BELOW	500# COLD SUPPLY UP
550# HOT SUPPLY FROM BELOW	400# HOT SUPPLY UP
600# COLD SUPPLY FROM BELOW	450# COLD SUPPLY UP
550# COLD SUPPLY FROM BELOW	450# COLD SUPPLY UP
600# COLD SUPPLY FROM BELOW	450# COLD SUPPLY UP
500# HOT SUPPLY FROM BELOW	450# HOT SUPPLY UP
550# HOT SUPPLY FROM BELOW	450# HOT SUPPLY UP
550# HOT SUPPLY FROM BELOW	450# HOT SUPPLY UP

FUME HOOD AIRFLOW (L/S)	FH12 425 BIO	FUME HOOD NUMBER	FH12 425 BIO	FUME HOOD TYPE
GENERAL EXHAUST RISER	GE1	FUME HOOD RISER	F1	