

Part 1 General

1.1 REFERENCES

- .1 ASTM International
 - .1 ASTM A123/A123M-13, Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products.
- .2 CSA International
 - .1 CSA O141-05, Softwood Lumber.
 - .2 CSA O325-07, Construction Sheathing.
- .3 National Lumber Grades Authority (NLGA)
 - .1 Standard Grading Rules for Canadian Lumber 2014.

1.2 QUALITY ASSURANCE

- .1 Lumber by grade stamp of an agency certified by Canadian Lumber Standards Accreditation Board.
- .2 Plywood panels in accordance with CSA standards.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.

Part 2 Products

2.1 FRAMING STRUCTURAL AND PANEL MATERIALS

- .1 Lumber: softwood, S4S, moisture content 19% (S-dry) or less in accordance with following standards:
 - .1 CSA O141.
 - .2 NLGA Standard Grading Rules for Canadian Lumber.
- .2 Furring, blocking, nailing strips, grounds, rough bucks, cants, curbs, fascia backing and profiles as indicated:
 - .1 Board sizes: "Standard" or better grade.
 - .2 Dimension sizes: "Standard" light framing or better grade.
- .3 Plywood panels: to CSA O325.
 - .1 Pressure treated with wood preservative for exterior applications and as indicated

2.2 ACCESSORIES

- .1 Fastener Finishes:
 - .1 Galvanizing: to ASTM A123/A123M, use galvanized fasteners for exterior work.

- .2 Wood Preservative:
 - .1 Surface-applied wood preservative: coloured alkaline copper quarternary (ACQ) applied to lumber and panel materials by pressurized process to minimum 0.25 pcf
 - .2 Liquid applied ACQ for site treatment for cut-ends and holes

Part 3 Execution

3.1 PREPARATION

- .1 Treat surfaces of material with wood preservative, before installation.
- .2 Apply preservative by dipping, or by brush to completely saturate and maintain wet film on surface for minimum 3 minute soak on lumber and one minute soak on plywood.
- .3 Re-treat surfaces exposed by cutting, trimming or boring with liberal brush application of preservative before installation.

3.2 MATERIAL USAGE

- .1 Hoarding wall sheathing:
 - .1 Plywood, DFP or CSP sheathing grade or PP standard sheathing grade, square edge, thickness as indicated.

3.3 INSTALLATION

- .1 Install members true to line, levels and elevations, square and plumb.
- .2 Construct continuous members from pieces of longest practical length.
- .3 Install furring and blocking as required to space-out and support facings, parapets and other work as required.
- .4 Refer to Section 01 56 00 –Temporary Barriers and Enclosures for installation of plywood sheathing at temporary hoarding.
- .5 Install wood cants, fascia backing, nailers, curbs and other wood supports as required and secure using galvanized fasteners.
- .6 Frame, anchor, fasten, tie and brace members to provide necessary strength and rigidity.
- .7 Countersink bolts where necessary to provide clearance for other work.

3.4 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by rough carpentry installation.

END OF SECTION

Part 1 General

1.1 REFERENCES

- .1 American Society for Testing and Materials International (ASTM)
 - .1 ASTM C 1002-14, Standard Specification for Steel Self-Piercing Tapping Screws for the Application of Gypsum Panel Products or Metal Plaster Bases to Wood Studs or Steel Studs.
 - .2 ASTM C 1177/C1177M-13, Standard Specification for Glass Mat Gypsum Substrate for Use as Sheathing
 - .3 ASTM C 1280-13A, Standard Specification for Application of Gypsum Sheathing
 - .4 ASTM C 1325-14, Standard Specification for Non-Asbestos Fiber-Mat Reinforced Cementitious Backer Units

1.2 SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets and include product characteristics, performance criteria, physical size, finish and limitations.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.

Part 2 Products

2.1 MATERIALS

- .1 Panel Materials:
 - .1 Glass mat water-resistant siliconized gypsum core sheathing board: to ASTM C1177.
 - .1 Thickness: as indicated.
 - .2 Size: nominal 1200mm wide x maximum practical length

2.2 ACCESSORIES

- .1 Screws: to ASTM C1002, corrosion resistant.

Part 3 Execution

3.1 EXAMINATION

- .1 Verification of Conditions: verify conditions of substrates previously installed or existing are acceptable for installation in accordance with manufacturer's written instructions.
 - .1 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .2 Proceed with installation only after unacceptable conditions have been remedied.

3.2 INSTALLATION

- .1 Comply with manufacturer's written data, including product technical bulletins, product catalogue installation instructions, product carton installation instructions, and data sheets.
- .2 Install gypsum core sheathing to steel studs and steel frame in accordance with ASTM C1280 and manufacturer's printed instructions.

3.3 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 00 10 - General Instructions.
 - .1 Leave Work area clean at end of each day.

END OF SECTION