



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Portable Air Conditioning Units	
Solicitation No. - N° de l'invitation W2671-15JG72/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client W2671-15JG72	Date 2015-11-30
GETS Reference No. - N° de référence de SEAG PW-\$EDM-206-10606	
File No. - N° de dossier EDM-5-38189 (206)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-12-15	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Peters, Brent	Buyer Id - Id de l'acheteur edm206
Telephone No. - N° de téléphone (780) 235-8279 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Amendment #001 is issued to make a change Item No. M3 of the Mandatory Requirements of Annex A and to the answer the following submitted questions:

Q1. Is a heat option required as well?

R1. No, but if heat is offered it will not disqualify the bidder nor will it give the bidder any advantage in the evaluation.

Q1. Are there any footprint restrictions?

R1. No. The units will be placed on grass next to the building. If the units arrive on a tractor trailer, the base has up to a 36 ton forklift to unload them.

Delete Annex A in its entirety and replace with the following:

ANNEX A – REQUIREMENT (REVISED)

The Department of National Defence (DND) Aerospace Engineering Test Establishment (AETE), Cold Lake, Alberta has a requirement for the supply and delivery of two (2), 25 ton portable air conditioning units. The units must be delivered on or before March 31, 2016.

REQUIREMENTS

Mandatory Criteria for the supply and delivery of two (2), portable 25 ton air conditioning units as well as the connection and control accessories as defined below:

Mandatory Requirements:

Item No.	Description	Met	Not Met	Bidder Provide Reference Location from Bid Document
M1	Air conditioning units must be portable. Air conditioning units must be trailer or skid mounted – if units are skid mounted, they must be forklift-able.			
M2	Air conditioning units must be at least 9000 CFM and must be a minimum of 25 TON with 20" supply air and 20" return air (connection is 20" to existing system).			
M3	Air conditioning units must be 125 Amp AC or less.			
M4	Air conditioning units must be 208 VAC 60 HZ 3 phase.			
M5	Air Conditioning units must be thermostatically controlled using a programmable electronic thermostat. The thermostat must have the ability to be programmed manually on the device by the end user, and must not require the use of external programming equipment.			
M6	Thermostat control cable must be weatherproof and a minimum of 100 ft. in length.			

Solicitation No. - N° de l'invitation
W2671-15JG72/A
Client Ref. No. - N° de réf. du client
W2671-15JG72

Amd. No. - N° de la modif.
001
File No. - N° du dossier
EDM 5-38189

Buyer ID - Id de l'acheteur
edm206
CCC No./N° CCC - FMS No./N° VME

Item No.	Description	Met	Not Met	Bidder Provide Reference Location from Bid Document
M7	Ducting must be weatherproof for outdoor use. Each air conditioning unit must have a minimum of 100 ft. of 20" supply air flexible ducting (qty. 2 per unit) and 100 ft. of 20" return air ducting (qty. 2 per unit). Return air ducting must not collapse under suction. If equipped with a rigid return duct directly connected to air conditioning unit the maximum length of the rigid ducting is 20 ft.			
M8	Each air conditioning unit must come with a minimum of 190 ft. and maximum of 200 ft. power cable that is detachable from the air conditioning unit and must be weatherproof. The power cable for each unit must connect to an AR1042 600 VAC 100 Amp Pin and Sleeve Receptacle 3-W 4-P.			
M9	Each unit must be supplied with a transformer converting 600 VAC to 208 VAC. The transformer must be either built into the power cable, or built into the air conditioning unit. If the transformer is built into the power cable, it must be 6-8 ft. from the receptacle end of the power cable.			
M10	All wiring connections must use weather tight receptacles.			

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME

Note:

If your bid has already been submitted and wish to revise it, revisions must be submitted in a sealed envelope or by facsimile on which the content is clearly written. Any revisions to your bid must be received by the Bid Receiving Unit on or before the time and date stated on page 1 of this document. Any revisions to your bid received after the closing date and time will be considered late and will be returned unopened.