



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Bid Receiving - PWGSC / Réception des soumissions
- TPSGC**

11 Laurier St. / 11 rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau

Quebec

K1A 0S5

Bid Fax: (819) 997-9776

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

Centre Block Rehabilitation Project/Projet de
réhabilitation de l'édifice du Centre
185 Sparks Street
185, rue Sparks
3rd Floor - 313/3ème étage - 313
Ottawa
Ontario
K1A 0S5

| | |
|--|---|
| Title - Sujet Emergency Power Modernization | |
| Solicitation No. - N° de l'invitation EP754-161586/A | Amendment No. - N° modif. 007 |
| Client Reference No. - N° de référence du client 20161586 | Date 2015-11-30 |
| GETS Reference No. - N° de référence de SEAG PW-\$\$\$FP-004-68288 | |
| File No. - N° de dossier fp004.EP754-161586 | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-12-07 | |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Burns, Heather | Buyer Id - Id de l'acheteur fp004 |
| Telephone No. - N° de téléphone (819) 775-5575 () | FAX No. - N° de FAX () - |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

EXTENSION TO BID CLOSING DATE

Please note that the tender Closing Date for this Project is hereby EXTENDED from December 3, 2015 to December 7, 2015.

ADDENDUM #4

See attached.

**PARLIAMENT HILL
EMERGENCY POWER UPGRADE (PHEP)**

PROJECT NO. R.011801.165

PAGE 1 of 3
DATE: November 30, 2015

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

DRAWINGS

1. DRAWING A200

- .1 DELETE Note 34 and ADD new Note 34 to read:

“Waterproofing membrane.”

- .2 DELETE Note 39 and ADD new Note 39 to read:

“Lap new waterproofing membrane over existing.”

- .3 ADD new Note 53 to read:

“Typical, add reinforcing fabric at all inside and outside corners, per manufacturer’s instructions.”

2. DRAWING A200, DETAIL 4

- .1 DELETE Note Reference 51 and ADD Note Reference 53 .

3. DRAWING S102 – TYPICAL & PROJECT DETAILS

- .1 T4001B: Add the following note: “ALL NEW MASONRY WALLS TO BE FULLY-GROUTED AS PER ARCHITECTURAL.”

4. DRAWING S220 – SUB-GRADE LEVEL 1 - NEW

- .1 At the block wall near gridline C, revise the note to: “REMOVE EXISTING BLOCK WALL. PROVIDE NEW WALL AS PER MECHANICAL.”

5. DRAWINGS S301 – BUILDING SECTIONS

- .1 ENLARGEMENT: Revise 15@30VEF to 15@300VEF.

**PARLIAMENT HILL
EMERGENCY POWER UPGRADE (PHEP)**

PROJECT NO. R.011801.165

PAGE 2 of 3
DATE: November 30, 2015

SPECIFICATIONS

1. SECTION 26 32 13.04 - DIESEL ELECTRIC GENERATING UNITS (LIQUID COOLED)

.1 Add Items 1.7.2.4 & 1.7.2.5 to read:

“.4 Access openings for equipment entry are approximately 5.3 m by 2.9 m, vertically aligned above generator room in configuration and geometry as indicated on plans.

.5 Final assembly and installation of equipment and related components on site must be completed by and certified by manufacturer's authorized representative.”

.2 Delete Item 2.4.3 and add new Item 2.4.3 to read:

“.3 Support engine/generator on seismically rated spring type isolating fixtures from steel base frame.”

.3 Delete Item 2.4.3.1 and add new Item 2.4.3.1 to read:

“.1 Isolators: cast iron housings, complete with levelling bolts, adjustable oil proof snubbers and minimum 6 mm sound pads, minimum 50 mm deflection.”

.4 Delete Item 2.8.1.1 and add new Item 2.8.1.1 to read:

“.1 Integrated fuel booster pump to be sized to overcome line pressure losses, anti siphon\solenoid valve and foot valve associated with external pipe system, and powered through generators battery circuit.”

.5 Delete Item 2.8.4 and add new Item 2.8.4 to read:

“.4 All components to be ULC listed for the intended purpose and be pre-wired and prepiped on engine frame and ready for connection to external fuel oil system.”

.6 Delete Item 2.9.3 and add new Item 2.9.3 to read:

“.3 Exhaust system from silencer outlet to termination outside to be provided by Div. 23. Generator Manufacturers are responsible for ensuring the generator and silencer supplied are suitable to accommodate the back pressure resulting from the venting size and configuration as illustrated on drawings and in accordance with Section 23 35 17 Generator Exhaust Venting. Extra costs associated with larger venting requirements to suit supplied generator and silencer will not be accepted.”

**PARLIAMENT HILL
EMERGENCY POWER UPGRADE (PHEP)**

PROJECT NO. R.011801.165

PAGE 3 of 3
DATE: November 30, 2015

.7 Add new Item 2.21.1.5 to read:

“.5 Kohler Power Systems”