



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works & Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax,(N.E.)
B3J 1T3
Halifax
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.E.)
B3J 3C9
Halifax
Nova Scot

Title - Sujet HVAC Controls & System Upgrade	
Solicitation No. - N° de l'invitation EB144-161601/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client EB144-16-1601	Date 2015-12-01
GETS Reference No. - N° de référence de SEAG PW-\$PWA-110-5314	
File No. - N° de dossier PWA-5-74121 (110)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-12-10	
Time Zone Fuseau horaire Atlantic Standard Time AST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Collier (PWA), Susan	Buyer Id - Id de l'acheteur pwa110
Telephone No. - N° de téléphone (902) 496-5350 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 006 is being raised to answer questions from the site visit as follows:

Delete in its entirety:

Listed under Electronic Attachments

Blandford Harbour

1. Questions and Answers:

	Question	Response
1	Are there drawings missing?	Yes – See Amendment 5
2	Will there be an extension?	Yes – See Amendment 5
3	What is the weight of the new roof mounted high-plume fans (FF-1 & FF-2)?	Weights of FF-1 and FF-2 are approximately 4100kg (total for fan package). See drawings H602 for fan dimensions and shipping splits.
4	Will the new EMCS be integrated with the existing system?	For information on EMCS integration with existing control system, see Specification division 25 05 01, sections 1.3.2 and 1.3.3.
5	Will the General Exhaust need to be stainless steel?	Reference drawing H308. Add to notes: <i>2) All new General Exhaust Plenum ductwork to be stainless steel to match existing General Exhaust Plenum. This includes all new ductwork adjacent to new fan GE-1.</i>
6	The stairs to the penthouse are narrow. How are materials to be brought to the penthouse and roof?	Materials can be brought to the roof using a crane stationed on the pavement in front of the building.
7	How do we fit structural components and materials in the penthouse considering the existing equipment and infrastructure?	Anything in the way of the new requirements will have to be removed or worked around.
8	Is there any asbestos in the building?	There is no known asbestos in the areas where work is required. If a suspected asbestos containing material is encountered during the construction contract, it is to be brought to the attention of PWGSC. A change order will be issued in order to test and remediate on a case-by-case basis. AAFC's Asbestos Management Plan will be provided to the successful bidder.
9	There are some room ceilings where drywall is indicated and noted to be replaced with ceiling tile. Are we to assume that ceilings which are not marked are also to be torn down for access and replaced with ceiling tile?	The following rooms in the C Section Lab Area have drywall ceilings which must be removed for access and replaced with ceiling tile: C-130, C-227, C-248, C-255, C-258, C-315 & C-359.
10	Where drywall ceilings are removed and replaced with ceiling tile, will new light fixtures need to be installed?	Yes.

11	Is the wiring be run in free air or in conduit above ceiling?	See Amendment 5, page 4 – Add to Section 01 10 10, 1.1.2.18 as follows: “.18 Control Wiring to be run in conduit in all exposed areas, including the Mechanical Penthouse, the Mechanical Chase, and the 1 st Floor Mechanical Room. Control wiring in ceiling plenums may be fun in free air on J-hooks. Control wiring drops in walls to sensors and devices to be run in conduit.”
12	Will the labs be emptied before construction?	No. The labs and fume hoods will be emptied of stored chemicals but care must be taken to control dust and debris, cover and protect equipment, and leave the lab items in the same condition as found.
13	Will the existing fume hoods be cleaned before removal?	Fume hoods will be surface cleaned only. Standard fume hoods will be wiped clean before removal. Per drawings H602: Percholic fume hoods and ductwork are to be cleaned by a laboratory duct cleaning specialist prior to removal. Reference Specification 23 38 00 - Cleaning of HVAC and Exhaust Systems.
14	What is the anticipated construction schedule?	Initial scheduling allows for a 7-month construction window. However, this will be negotiated and developed with the successful bidder per their input and recommendations.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.