



Q&A #1

Date: December 1st, 2015

Project: Entomology Lab project in St-John's

Bidders must make sure that their bids are based on the latest version of the tender documents published and take into consideration the following amendments and information, including any information provided in amendments or Q&As previously published for this project.

Bidders that do not comply with this requirement will be discarded.

Question 1: Is the CertainTeed Performa RX Symphony m 2x2x15/16" ceiling tile considered as an acceptable alternate to Armstrong Ultima Health Zone 2x2-15/16" ceiling tile?

Answer 1: Yes, the CertainTeed Performa RX Symphony m 2x2x15/16" ceiling tile is an acceptable alternative for the Armstrong Ultima Health Zone 2x2 – 15/16 ceiling tile.

Question 2: Is the Metalux 14GR LED 1'x4' LED recessed troffer light considered an acceptable alternative to the 300 mm x 1200mm Phillips #AA248 recessed LED light fixture?

Answer 2: Yes, the Metalux 14GR LED 1'x4' LED recessed troffer light considered an acceptable alternative to the 300 mm x 1200mm Phillips #AA248 recessed LED light fixture.

All other conditions and requirements remain unchanged.