



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency**  
**1300 - 635 8 Ave SW**  
**Calgary, AB T2P3M3**  
**Bid Fax: (403) 292-4475**

**AMENDMENT / MODIFICATION**

**005**

**Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

**Parks Canada Agency**  
**Suite 1300**  
**635 - 8 Ave SW**  
**Calgary, AB T2P3M3**

<b>Title-Sujet</b> Edith Pass Trail Bridge Banff National Park		
<b>Solicitation No. - No. de l'invitation</b> 5P420-15-5239/A	<b>Date:</b> December 4, 2015	
<b>GETS Reference No. - No de reference de SEAG</b> PW-15-00707358	<b>Amendment No. - N° de la modif.</b> 005	
<b>Solicitation Closes:</b>		
<b>at - á</b> 02:00 PM	<b>on - le</b> December 8, 2015	<b>Time Zone - Fuseau horaire</b> MST - HNR
<b>F.O.B. - F.A.B.</b>		
<b>Plant-Usine:</b> <input type="checkbox"/>	<b>Destination:</b> <input checked="" type="checkbox"/>	<b>Other-Autre:</b> <input type="checkbox"/>
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b>		
Jen Maheu		
<b>Telephone No. - No de téléphone</b>	<b>Fax No. - No de FAX:</b>	
(403) 292-8502	(403) 292-4475	
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b>		
See Herein - Voir ici		

**TO BE COMPLETED BY THE BIDDER (type or print)**

<b>Vendor/Firm Name</b>	
<b>Address - Adresse</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b> <b>Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Titale - Titre</b>	
<b>Telephone No. - N° de telephone:</b>	_____
<b>Facsimile No. - N° de télécopieur:</b>	_____
<b>Signature</b>	<b>Date</b>

## **Amendment 05**

This amendment is issued to summarize the questions and answers provided at the November 24th site visit, answer bidder questions submitted by email and provide additional documents.

<b>Company</b>	<b>Representative</b>
Lundstrom Construction	Brian Lundstrom
Oskar Construction	Stu Mills

### **1. SITE VISIT QUESTIONS**

- Q1 Where can clean gravel exaction material be hauled to?
- A1 Clean fill can be hauled to a Pit of the Departmental Representatives choosing (Cascade Pit or Peyto Pit) near the Town of Banff or be disposed of outside of the Park.
- Q2 Where can trees be disposed?
- A2 Logs suitable for firewood can be hauled to Peyto Pit. All brush and other organic debris is to be disposed of outside of the Park.

### **2. BIDDER QUESTIONS**

- Q3 All additional steel for the modifications is noted on the drawings as being a 350AT steel, also known as weathering steel. These form an oxide layer when exposed to the atmosphere, preventing further corrosion; these typically do not require protective coatings. Is the requirement for the inorganic zinc primer and/or the steel type correct?
- A3 The new 350AT steel does not need to be painted with an inorganic zinc primer. However the faying surfaces for any of the new plates that are part of bolted connections requires blast cleaning to SSPC-SP10.
- Q4 Would you please clarify what the steel type is on the existing steel structure? This will be necessary to determine the electrode / wire used for welding the new steel to the existing steel.
- A4 The existing steel is 300W material.
- Q5 How long will heat be required to be on the abutments once they've been poured?
- A5 We require heating for 7 days.

### **3. ADDITIONAL DOCUMENTS**

See the following attachments for this solicitation:

Fisheries and Oceans Canada Measures to Avoid Harm to Fish and Fish Habitat.pdf  
Edith Pass Trailhead Bridge Mitigation Measures.pdf

**All other terms and conditions remain unchanged.**