



Royal Canadian Mounted Police Gendarmerie royale du Canada

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS**

Bid Receiving/Réception des soumissions

Bid Receiving Unit/Groupe de la réception des soumissions

Procurement & Contracting Services Branch, Visitors Centre
Royal Canadian Mounted Police
73 Leikin Drive,
Ottawa, ON K1A 0R2
(613) 843-3798

Facsimile Number for Amendments: 613-825-0082

AMENDMENT - INVITATION TO TENDER

MODIFICATION - APPEL D'OFFRES

Tender to: Royal Canadian Mounted Police

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

Soumission aux: Gendarmerie royale du Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Facsimile No. - No de télécopieur:

Telephone No. - no de telephone:

Title-Sujet: Hangar Door Replacement	
Solicitation No. - No. de l'invitation 201603361	Date Dec 4, 2015
Client Reference No. - No. De Référence du Client 201603361	Amendment No. - N° du modification 006
GETS Reference No. - No. de Référence de SEAG 201603361	
Solicitation Closes -L'invitation prend fin at - à 2:00 pm EST on - le Dec 8, 2015	
F.O.B. - F.A.B. Destination	
Address Enquiries to: - Adresser toutes questions à: dale.rudderham@rcmp-grc.gc.ca	
Telephone No. - No de telephone 613-843-5313	Fax No. - N° de FAX: 613-825-0082
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: RCMP/GRC 3257 Carp Rd. Carp ON.	
This document contains a Security Requirement	
Delivery Required - Livraison exigée: See Herein	Delivery Offered - Livraison proposée
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur	



A **signed** amendment cover page should accompany your bid.

Amendment006 to ITT 201603361 is created to provide Questions & Answers Part 2 and provide Addendum003 to the specification and drawings, and provide the Site Visit sign in sheet as follows:

1. Questions & Answers Part 2:

- Q44. Amendment No. 003 Q17. The answer for details for relocating an existing ground wire is Note 18 on Drawing E-1. The drawings I have been supplied to quote for this job have only 12 Notes. Either please supply me with a new drawing or confirm that this answer is not accurate.
- A44. ***Please refer to E-1 issued for Tender dated 30-10-2015.***
- Q45. Same for Q18 and answer 18 ... Notes 21 and 22 on E-1?? my notes go up to 12 only. Please clarify.
- A45. ***Please refer to E-1 issued for Tender dated 30-10-2015.***
- Q46. The Push Buttons supplied by the door operator are they 600V? if not what control wiring from the door motor exists? If the controls are from the "one breaker for controls at 120V" from Note 3, then there is 2 different sources of power at the motor; which can be acceptable; however, prudence request a wiring schematic for this motor and PB controls. Since it is mentioned the door controls need to be in a NEMA 12 enclosure; what size? What else beside the horn is tied into the controls? Door contacts?
- A46. ***Coordinate with Hanger door manufacturer for requirements.***
- Q47. According to the specs, a horn is signalled when the door is pressed; is the electrical contractor installing this horn? need spec and location if "yes". Please clarify.
- A47. ***Coordinate with Hanger door manufacturer for requirements.***
- Q48. Is there a sketch to show the physical installation of the motors and their control? example ... how far away is the motor from the JB in the corner? Is the motor mounted on the ground? a rack? also need to know the height of the motor since any electrical below 18" must be explosion proof. Please clarify.
- A48. ***Coordinate with Hanger door manufacturer for requirements.***
- Q49. Is there any layout and schematic for the heating snow melt cables? Where is the connection for the circuit? Is there a control JB we terminate in to? Does this control box need to be NEMA 12 as well? Are the snow sensors existing? Are the snow sensors wired to this control JB? Please clarify.
- A49. ***Refer to drawing note 14 on E-1 & specifications.***
- Q50. Is there any layout and schematic for the "miscellaneous circuit" from Note 3? Please clarify.
- A50. ***All circuits are shown on drawing E-1 dated 30-10-2015.***
- Q51. Further to Q&A20, we've now been issued the type of materials required, but the connection to the new steel structure has not been addressed. Are we to use Z-bar fastened to the new steel and what type of fasteners ... screws, ramset?
- A51. ***Refer to item 2.3 as part of specification section 07 46 13.***



- Q52. Q&A22 States "See note A1". I don't have a drawing note A1 on my drawings. Please provide.
A52. **Please refer to A1 (Answer to Q1 Questions and Answers Part 1).**
- Q53. Q&A29 states "See note 17 on E-1". There is no note 17 on my drawings. Please provide.
A53. **Please refer to E-1 issued for Tender dated 30-10-2015.**
- Q54. Further to Q&A42, are we to use the siding spec'd as the exterior cover for the doors?
A54. **Yes, please refer to specification section 07 46 13.**
- Q55. Exterior skin & insulation (100 mm layers of minimal fiber – Roxul) of doors by General Contractor; Hopefully we can get a little more clarification on this statement. Are you saying the interior of the sliding door is to receive 100 mil of Roxul insulation or is the roofing / siding above to receive the Roxul?
A55. **Two layers of 100mm of mineral fiber "Roxul" is to be installed within hanger door cavity.**
- Q56. My drawings for buy and sell are labeled 99% is there drawings that say tender issued?
A56. **Please consider Architectural drawings issued as 99% review to be Tender drawings.**
- Q57. What is the location of the nearest drainage point?
A57. **Please allow for 60m, identify this work as a line item in the quotation. Further clarification will be provided by the client during construction and cost for this work will be adjusted accordingly.**
- Q58. Amendment #3 states "Also see attached specification section 31 31 13 for chain link fence and gates" on the last note, however, we have not received seen any specification for such.
A58. **Please see specification section 32 31 13.**

-See specification sections 22 13 17 & 22 42 01 in response to question Q40.

-To clarify our response to question Q31 please note the following. The insulation to be used against the existing foundation wall as no structural or thermal purposes and can consist any of extruded polystyrene, 4 layers of 50mm thick panels.

-See specification section 32 12 16.01 for reinstatement of asphalt pavement. An inspection will be performed by the Client during construction and any deviation from the specifications and drawings will be amended accordingly which may or may not be an extra cost.

-Please disregard item 1.1.1 from specification section 07 21 16 "Blanket Insulation" as it is not applicable to the scope of work.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME

HANGAR DOOR REPLACEMENT

Nov. 19/15 1000

<u>NAME</u>	<u>REPRESENTING</u>	<u>EMAIL</u>	<u>NDA</u>
GARY CODEGNO	TENNIX CONSTRUCTION	gcodogno@tennixcorp.ca	✓
Robert Buckley	McDonald Bros. Construction	robert@mbconstruction.ca	✓
MARIO GERN	PIVOTECH DOORS INC.	MARIO@PIVOTECHDOORS.COM	✓
KEITH RILEY	ARGUE CONSTRUCTION	keith@argueconstruction.ca	✓
PATRICK ENGLAND	W&A	patrick@woodward.ca	✓
RICHARD BUTLER	RAYMOND ROOFING	r.butler@raymondroofing.ca	✓
TIM FOSS	DMB	tim@dmconstruction.ca	✓
Andrew Splinter	Dolyn	estimating@dolyn.com	✓
Linda Barkley	Daoust Gint	linda@dgc.ca	✓
BRUCE ROMANO	MASSILOTTE CONST	BRUCE@MASSILOTTE-GRP.COM	✓
IGOR TORBIS	TUNEC CONSTRUCTION	igor@tunec.ca	✓
Alex Buckland	AMBICO LTD	Abuckland@ambico.com	✓

~~Handwritten scribbles at the top right of the page.~~

Handwritten text at the top left, possibly a date or page number.

Handwritten text at the top center, possibly a title or header.

<u>NAME</u>	<u>ADDRESS</u>	<u>RESIDENTIAL</u>	<u>NAME</u>
[Faint handwritten name]	[Faint handwritten address]	[Faint handwritten residential info]	[Faint handwritten name]
[Faint handwritten name]	[Faint handwritten address]	[Faint handwritten residential info]	[Faint handwritten name]
[Faint handwritten name]	[Faint handwritten address]	[Faint handwritten residential info]	[Faint handwritten name]
[Faint handwritten name]	[Faint handwritten address]	[Faint handwritten residential info]	[Faint handwritten name]
[Faint handwritten name]	[Faint handwritten address]	[Faint handwritten residential info]	[Faint handwritten name]
[Faint handwritten name]	[Faint handwritten address]	[Faint handwritten residential info]	[Faint handwritten name]

Handwritten mark at the bottom right corner.