

FUME HOOD SCHEDULE

TAG	LOCATION	SIZE	TYPE	SERVICES				BASE CABINET STORAGE REQUIREMENTS (SEE NOTE 1)
				WATER	# OF OUTLETS	AIR	# OF OUTLETS	
1	LAB 115	1830	VAV FUME HOOD	YES	1	YES	2	1A, 1F
2	LAB 115	1830	VAV FUME HOOD	YES	1	YES	2	2F
3	LAB 115	1830	VAV FUME HOOD	YES	1	YES	2	2F
4	LAB 115	1830	VAV FUME HOOD	YES	1	YES	2	2F
5	LAB 115	1830	VAV FUME HOOD	YES	1	YES	2	1B, 1F
6	LAB 165	1830	VAV FUME HOOD	YES	1	YES	2	1B, 1F
7	LAB 165	1830	VAV FUME HOOD	YES	1	YES	2	2F
8	LAB 165	1830	VAV FUME HOOD	YES	1	YES	2	2F
9	LAB 165	1830	VAV FUME HOOD	YES	1	YES	2	2F
10	LAB 165	1830	VAV FUME HOOD	YES	1	YES	2	1A, 1F
11	LAB 165A	1830	VAV FUME HOOD	YES	1	YES	2	1A, 1F
12	LAB 225	2240	SUPPLIED BY OWNER	YES	1	YES	2	1A, 1F (SEE NOTE 2)
13	LAB 225	1830	VAV FUME HOOD	YES	1	YES	2	2F
14	LAB 225	1830	VAV FUME HOOD	YES	1	YES	2	2F
15	LAB 225	1830	VAV FUME HOOD	YES	1	YES	2	2F
16	LAB 225	1830	VAV FUME HOOD	YES	1	YES	2	2F
17	LAB 225	1830	VAV FUME HOOD	YES	1	YES	2	2F
18	LAB 225	1830	VAV FUME HOOD	YES	1	YES	2	2F
19	LAB 225	1830	VAV FUME HOOD	YES	1	YES	2	2F
20	LAB 225	1830	CLASS II B1 SAFETY CABINET	YES	1	YES	2	1B, 1F

- NOTES:
1. STORAGE BASE REQUIREMENTS ARE AS FOLLOWS:
1A = SINGLE ACID CABINET
1F = SINGLE FLAMMABLE CABINET
2F = TWO(2) FLAMMABLE CABINETS
2. PROVIDE ADDITIONAL FILTER PIECES AS REQUIRED.

REFERENCE:
DRAWING M3.5, PARTIAL PENTHOUSE PLAN,
HVAC LAYOUT, SECTION & SCHEDULES

PROJECT:

TORONTO HEALTH CANADA, 2301 MIDLAND AVE.,
LABORATORY UPGRADES

TITLE:

FUME HOOD SCHEDULE REVISION



1345 ROSEMOUNT AVENUE
CORNWALL, ONTARIO
CANADA K6H 3E5
PHONE: 613-943-3802 FAX: 613-936-0335
WWW.WSPGROUP.COM

SCALE:
N.T.S.

DATE:
DECEMBER 2, 2015

PROJECT NO:
121-15142-00

DRAWING NO:
MD.1