



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jaspe
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Safety Valves	
Solicitation No. - N° de l'invitation W0134-15L968/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client W0134-15L968	Date 2015-12-04
GETS Reference No. - N° de référence de SEAG PW-\$EDM-607-10617	
File No. - N° de dossier EDM-5-38208 (607)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-12-07	
Time Zone Fuseau horaire Mountain Standard Time MST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Jenkinson, Lorraine	Buyer Id - Id de l'acheteur edm607
Telephone No. - N° de téléphone (780) 497-3593 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
W0134-15L968/A
Client Ref. No. - N° de réf. du client
W0134-15L968

Amd. No. - N° de la modif.
003
File No. - N° du dossier
EDM-5-38208

Buyer ID - Id de l'acheteur
edm607
CCC No./N° CCC - FMS No./N° VME

Title: Safety Valves

This solicitation amendment is to provide for clarifications regarding the Solicitation.

PART A: QUESTIONS/ANSWERS

Q1-1. I am just finalizing my bid, there is one issue with the [mandatory criteria]. I had supplied our valve sizings and they are sizes based upon the orifice area. As noted in my previous email, every manufacturer's valves have slight differences. Our rated capacity on the valve set at 130 PSI would be 29,128 Lb/Hr and on the valve set at 135 Psi it would be 30,137 Lb/Hr. You have changed everything on the addendum to allow us to quote except the capacity rating with ours being a miniscule amount below the Farris valves.

I know that we are getting [close to the bid closing date] but is it possible to have this revised to a minimum of our rated capacity?

A1-1. The specifications and mandatory criteria have been revised. .

PART B: REVISION TO SOLICITATION DOCUMENT

B1.1 At ANNEX "A" – REQUIREMENT

DELETE: ANNEX "A" – REQUIREMENT (Revised 2015-11-27), in its entirety.
INSERT: ANNEX "A" – REQUIREMENT, (Revised 2015-12-04), per attached.

B1.2 At ANNEX "B" – EVALUATION CRITERIA

DELETE: ANNEX "B" – EVALUATION CRITERIA (Revised 2015-11-18), in its entirety.
INSERT: ANNEX "B" – EVALUATION CRITERIA (Revised 2015-12-04), per attached.

If your bid has already been submitted, you may wish to revise it. Revisions to your bid must be submitted in a sealed envelope or by facsimile on which the content is clearly written. Any revisions to your bid must be received by the Bid Receiving Unit on or before the time and date stated on page 1 of this document. Any revisions to your bid received after the closing date and time will be considered late and will be returned unopened.

**ANNEX "A" – REQUIREMENT
(Revised 2015-12-04)**

Instruction to Bidders:

- Bidders are requested to complete the table below and submit the completed table with their bid.
- Firm Unit Prices and Firm Lot prices are FOB Destination and include all delivery charges.
- Firm Unit Prices do not include Applicable Taxes. Applicable Taxes will be added as a separate line item to any invoice issued as a result of a Contract.
- All Firm Unit Prices are in Canadian Dollars.

Safety valves are required at 4 Wing Cold Lake. The valves are an important part of the central heating plant.

Item	Description	Qty [A]	Firm Unit Price [B]	Extended Price [A x B]
A.	Purchase from contract award to 2016-03-31.			
1.	42NA12-170/00 SAFETY VALVE - 4" 300lb RF INLET, 6" 150lb RF OUTLET, 4.4454 sq. in - 4.471 sq. in FLOW AREA, ORFICE Diameter Minimum 2.000 -3.000in, LIFT between 0.588 in to 0.597in, SET PRESSURE RANGE 130 psig, SECTION 1 STEAM SERVICE <i>maximum</i> of 29836lbs/hr., STEAM MEDIA. MUST HAVE CANADIAN REGISTRATION NUMBER (CRN). MUST COME WITH MANUAL LIFTING LEVER AS STANDARD.	3	\$	\$
2.	42NA12-170/00 SAFETY VALVE – 4" 300lb RF INLET, 6" 150lb RF OUTLET, 4.3858 sq. in to 4.471 sq. in FLOW AREA, ORFICE Diameter Minimum 2.000 -3.000in, LIFT 0.588 in to 0.597 in., SET PRESSURE RANGE 135 psig, SECTION 1 STEAM SERVICE <i>maximum</i> of 30456lbs/hr., STEAM MEDIA. MUST HAVE CANADIAN REGISTRATION NUMBER (CRN). MUST COME WITH MANUAL LIFTING LEVER AS STANDARD.	1	\$	\$
B.	Optional Purchase: 2016-04-01 to 2017-03-31			
1.	42NA12-170/00 SAFETY VALVE - 4" 300lb RF INLET, 6" 150lb RF OUTLET, 4.4454 sq. in - 4.471 sq. in FLOW AREA, ORFICE Diameter Minimum 2.000 -3.000in, LIFT between 0.588 in to 0.597in, SET PRESSURE RANGE 130 psig, SECTION 1 STEAM SERVICE <i>maximum</i> of 29836lbs/hr., STEAM MEDIA. MUST HAVE CANADIAN REGISTRATION NUMBER (CRN). MUST COME WITH MANUAL LIFTING LEVER AS STANDARD.	2	\$	\$

Solicitation No. - N° de l'invitation
W0134-15L968/A
Client Ref. No. - N° de réf. du client
W0134-15L968

Amd. No. - N° de la modif.
003
File No. - N° du dossier
EDM-5-38208

Buyer ID - Id de l'acheteur
edm607
CCC No./N° CCC - FMS No./N° VME

2.	42NA12-170/00 SAFETY VALVE – 4” 300lb RF INLET, 6” 150lb RF OUTLET, 4.3858 sq. in to 4.471 sq. in FLOW AREA, ORFICE Diameter Minimum 2.000 -3.000in, LIFT 0.588 in to 0.597 in., SET PRESSURE RANGE 135 psig, SECTION 1 STEAM SERVICE <i>maximum</i> of 30456lbs/hr., STEAM MEDIA. MUST HAVE CANADIAN REGISTRATION NUMBER (CRN). MUST COME WITH MANUAL LIFTING LEVER AS STANDARD.	4	\$	\$
				Subtotal:
				Taxes and Customs fees:
				Transportation:
				TOTAL BID PRICE (\$CAN):

2. Delivery Date

2.1 Purchases from contract award to 2016-03-31.

While delivery is requested by 2015-12-15, the best delivery that could be offered is _____.

2.2 Optional Purchase: 2016-04-01 to 2017-03-31

The Contractor must make the complete delivery within _____ calendar days from the effective date of the order.

3. Delivery Address:

WING COMMANDER
4 WING COLD LAKE
BLDG 171-MDCAUN: CE SUPPLY
COLD LAKE, AD T9M 2C6

**ANNEX "B" – EVALUATION CRITERIA
(Revised 2015-12-04)**

Bidders must address any concerns with the mandatory technical specifications, in written detail to the Contracting Authority before bid closing as outlined in the solicitation.

1. Minimum performance specifications applicable to safety valves for steam

Safety Valve #1		MET / NOT MET	Identify where the supporting documentation is located the Bid (i.e. page #)
MUST HAVE	- 4" 300lb RF INLET x 6" 150lb RF OUTLET		
MUST HAVE	- 4.4454 sq. in - 4.471 sq. in FLOW AREA		
MUST HAVE	- ORFICE Diameter Minimum 2.000 -3.000in		
MUST HAVE	- LIFT between 0.588 in to 0.597in		
MUST HAVE	- SET PRESSURE RANGE 130 psig		
MUST HAVE	- SECTION 1 STEAM SERVICE maximum of 29836lbs/hr.		
MUST ACCOMMODATE	- STEAM MEDIA		
MUST HAVE	- CANADIAN REGISTRATION NUMBER (CRN)		
MUST COME WITH	- MANUAL LIFTING LEVER AS STANDARD		

Safety Valve #2 —		MET / NOT MET	Identify where the supporting documentation is located the Bid (i.e. page #)
MUST HAVE	- 4" 300lb RF INLET x 6" 150lb RF OUTLET		
MUST HAVE	- 4.3858 sq. in to 4.471 sq. in FLOW AREA		
MUST HAVE	- ORFICE Diameter Minimum 2.000 -3.000in		
MUST HAVE	- LIFT between 0.588 in to 0.597in		
MUST HAVE	- SET PRESSURE RANGE 135 psig		
MUST HAVE	- SECTION 1 STEAM SERVICE maximum of 30456 lbs/hr.		
MUST ACCOMMODATE	- STEAM MEDIA		
MUST HAVE	- CANADIAN REGISTRATION NUMBER (CRN)		
MUST COME WITH -	- MANUAL LIFTING LEVER AS STANDARD		

Solicitation No. - N° de l'invitation

W0134-15L968/A

Client Ref. No. - N° de réf. du client

W0134-15L968

Amd. No. - N° de la modif.

003

File No. - N° du dossier

EDM-5-38208

Buyer ID - Id de l'acheteur

edm607

CCC No./N° CCC - FMS No./N° VME

-
2. The Bidder must provide supporting technical documentation for the product offered. Technical brochures or technical data must be provided to verify compliance with the mandatory technical specifications.
 3. The bidder must indicate in its bid where the product offered meets each item. If no documentation is available, the bidder must indicate 'Not available'. When such information is not available, the bidder must say how it meets this specification.

The bidder certifies that the products offered meets the requirement and the minimum performance specifications above.

Signature

Date

Bids that do not meet all the requirements and all the mandatory technical specifications described above will be deemed non-responsive and given no further consideration.

If, upon delivery and acceptance, the product is found to not meet the Mandatory Technical Specifications, the product will be returned at the supplier's expense and the Contract will be terminated for default.