



Q&A #4

Date: December 7th, 2015

Project: Entomology Lab project in St-John's

Bidders must make sure that their bids are based on the latest version of the tender documents published and take into consideration the following amendments and information, including any information provided in amendments or Q&As previously published for this project.

Bidders that do not comply with this requirement will be discarded.

Question:

Is the Lithonia GTL4 LED 1'x4' LED recessed troffer light is considered an acceptable alternative to the 300 mm x 1200mm Phillips #AA248 recessed LED light fixture?

Answer:

Reference Drawing E1-R0 Existing/Demolition/New Level Floor Plans

The Lithonia GTL4 LED 1'x4' LED recessed troffer light is considered an acceptable alternative to the 300 mm x 1200mm Phillips #AA248 recessed LED light fixture.

All other conditions and requirements remain unchanged.