



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works & Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax,(N.E.)
B3J 1T3
Halifax
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.E.)
B3J 3C9
Halifax
Nova Scot

Title - Sujet HVAC Controls & System Upgrade	
Solicitation No. - N° de l'invitation EB144-161601/A	Amendment No. - N° modif. 010
Client Reference No. - N° de référence du client EB144-16-1601	Date 2015-12-08
GETS Reference No. - N° de référence de SEAG PW-\$PWA-110-5314	
File No. - N° de dossier PWA-5-74121 (110)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-12-15	
Time Zone Fuseau horaire Atlantic Standard Time AST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Collier (PWA), Susan	Buyer Id - Id de l'acheteur pwa110
Telephone No. - N° de téléphone (902) 496-5350 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 010 is being issued to revise specification and to incorporate the following:

Delete in its entirety:

Section 23 33 16 2.1.6

Insert:

Section 23 33 16 2.1.6

- to be read as follows:

“.6 Acceptable Manufacturers:

.1 Controlled Air Type B and C, Nailor Type B and C."

Question 1:

Request for Equal, Reference Specification Section 23 34 00.10:

Mix flow induced dilution high plume fans cook model QMXVP

Answer 1:

Cook Model QMXVP not approved.

Reasons, see Specification Section 23 34 00.10 2.1:

- No Outlet Windband-Silencer c/w stainless steel liner included.
- Epoxy coating to be 8-10 mls, not 5 mls as stated in literature.
- Insulated roof curb required.
- Dilution rate to be 194%, not 138% as noted.
- Bypass damper to be automatic not manual.

Delete in its entirety:

Reference Specification Section 23 38 16.13:

Insert:

Reference Specification Section 23 38 16.13:

Revise 23 38 16.13, 2.10.2.1 to read as follows:

“.1 Acceptable Manufacturers:

.1 Mott, Labconco, Bedco Lab, Waldner, Price-Kewaunee."

Question 2:

Request for Equal and acceptance as an alternate, our high performance F-350 Generation 5 - Isolator3 series fume hood

Answer 2:

The Jamestown Fume Hoods are not acceptable. The proposed fume hood documentation does not meet Specification Section 23 38 16.13 for the following reasons:

Section 23 38 16.13 1.2 & 1.7: No confirmation that PWGSC Guideline MD15128-2013 can be met.

Section 23 38 16.13 1.2: No confirmation that SEFA 1,2,3,& 7 can be met.

Section 23 38 16.13 2.3.8: Sash chain drive mechanisms are not acceptable.

Section 23 38 16.13 2.2.8.2: Spring return to 18" is indicated, but Spring counterbalance mechanisms are not acceptable.

Section 23 38 16.13 2.2: No hood performance data provided for the specified 100 fpm operation.

Section 23 38 16.13 2.3.11: Horizontal airfoil must be 316 stainless steel.

Section 23 38 16.13 2.1.2: No confirmation that units are pre-piped and pre-wired for single point connections.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.