

1 General

1.1 REFERENCED SECTIONS

- .1 Section 21 05 01 - Common Work Results – Mechanical.
- .2 Section 25 01 11 - EMCS: Start-up, Verification and Commissioning.
- .3 Section 25 05 01 - EMCS: General Requirements.

1.2 SUBMITTALS

- .1 Make submittals in accordance with Section 01 33 00 - Submittal Procedures and this section.
- .2 Submit preliminary design document within five (5) working days after Tender closing and before contract award, for review by the Departmental Representative.
- .3 Shop Drawings to consist of one (1) hard copy and one (1) soft copy (.pdf format) of design documents, shop drawings, product data and software.
- .4 Hard copy to be completely indexed and coordinated to assure compliance with contract requirements and arranged in same sequence as specification and cross-referenced to specification section and paragraph number.
- .5 Soft copy to be in AutoCAD - latest version and *.pdf format, structured using menu format for easy loading and retrieval on OWS.

1.3 DESIGN REQUIREMENTS

- .1 Preliminary Design Review: to contain following contractor and systems information.
 - .1 Location of local office.
 - .2 Description and location of installing and servicing technical staff.
 - .3 Location and qualifications of programming design and programming support staff.
 - .4 List of spare parts.
 - .5 Location of spare parts stock.
 - .6 Names of sub-contractors and site-specific key personnel.
 - .7 Sketch of site-specific system architecture.
 - .8 Specification sheets for each item including memory provided, programming language, speed, type of data transmission.
 - .9 Descriptive brochures.
 - .10 Sample CDL and graphics (systems schematics).
 - .11 Response time for each type of command and report.
 - .12 Item-by-item statement of compliance.
 - .13 Proof of demonstrated ability of system to communicate utilizing BACnet.

1.4 PRELIMINARY SHOP DRAWING REVIEW

- .1 Submit preliminary shop drawings within 30 working days of award of contract and include following:

- .1 Specification sheets for each item. To include manufacturer's descriptive literature, manufacturer's installation recommendations, specifications, drawings, diagrams, performance and characteristic curves, catalogue cuts, manufacturer's name, trade name, catalogue or model number, nameplate data, size, layout, dimensions, capacity, other data to establish compliance.
- .2 Detailed system architecture showing all points associated with each controller, signal levels, pressures where new EMCS ties into existing control equipment.
- .3 Spare point capacity of each controller by number and type.
- .4 Controller locations.
- .5 Auxiliary control cabinet locations.
- .6 Single line diagrams showing cable routings, conduit sizes, spare conduit capacity between control centre, field controllers and systems being controlled.

1.5 DETAIL SHOP DRAWING REVIEW

- .1 Submit detailed shop drawings within 60 working days after award of contract and before start of installation and include following:
 - .1 Corrected and updated versions (hard copy only) of submissions made during preliminary review.
 - .2 Wiring diagrams.
 - .3 Piping diagrams and hook-ups.
 - .4 Interface wiring diagrams showing termination connections and signal levels for equipment to be supplied by others.
 - .5 Shop drawings for each input/output point, sensors, transmitters, showing information associated with each particular point including:
 - .1 Sensing element type and location.
 - .2 Transmitter type and range.
 - .3 Associated field wiring schematics, schedules and terminations.
 - .4 Pneumatic schematics and schedules.
 - .5 Complete Point Name Lists.
 - .6 Set-points, curves or graphs and alarm limits (high and low, 3 types critical, cautionary and maintenance), signal range.
 - .7 Software and programming details associated with each point.
 - .8 Manufacturer's recommended installation instructions and procedures.
 - .9 Input and output signal levels or pressures where new system ties into existing control equipment.
 - .6 Control schematics, narrative description, CDL's fully showing and describing automatic and manual procedure required to achieve proper operation of project, including under complete failure of EMCS.
 - .7 Graphic system schematic displays of air and water systems with point identifiers and textual description of system, and typical floor plans as specified.
 - .8 Complete system CDL's including companion English language explanations on same sheet but with different font and italics. CDL's to contain specified energy optimization programs.
 - .9 Listing and example of specified reports.
 - .10 Listing of time of day schedules.
 - .11 Mark up to-scale construction drawing to detail control room showing location of equipment and operator work space.

- .12 Type and size of memory with statement of spare memory capacity.
- .13 Full description of software programs provided.
- .14 Sample of "Operating Instructions Manual" to be used for training purposes.
- .15 Outline of proposed start-up and verification procedures. Refer to Section 25 01 11 - EMCS: Start-up, Verification and Commissioning.

1.6 QUALITY ASSURANCE

- .1 Preliminary Design Review Meeting: Convene meeting within 45 working days of award of contract to:
 - .1 Undertake functional review of preliminary design documents, resolve inconsistencies.
 - .2 Resolve conflicts between contract document requirements and actual items (e.g.: points list inconsistencies).
 - .3 Review interface requirements of materials supplied by others.
 - .4 Review "Sequence of Operations".
- .2 Contractor's programmer to attend meeting.
- .3 Departmental Representative retains right to revise sequence or subsequent CDL prior to software finalization without additional costs.

2 Products

2.1 NOT USED

- .1 Not Used.

3 Execution

3.1 NOT USED

- .1 Not Used.

END OF SECTION