



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet BNP Wastewater System Upgrade	
Solicitation No. - N° de l'invitation E0209-161419/A	Amendment No. - N° modif. 007
Client Reference No. - N° de référence du client Parks-E0209-161419	Date 2015-12-14
GETS Reference No. - N° de référence de SEAG PW-\$PWU-201-10619	
File No. - N° de dossier PWU-5-38238 (201)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2015-12-17	Time Zone Fuseau horaire Mountain Standard Time MST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ho (RPC), Hector	Buyer Id - Id de l'acheteur pwu201
Telephone No. - N° de téléphone (780) 901-0989 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
E0209-161419/A
Client Ref. No. - N° de réf. du client
E0209-161419

Amd. No. - N° de la modif.
007
File No. - N° du dossier
PWU-5-38238

Buyer ID - Id de l'acheteur
pwu201
CCC No./N° CCC - FMS No./N° VME

This Amendment #007 has been raised to answer the following question:

Question 56

From what I can make out from the one picture of the panel that was taken, it is a Westinghouse and that brand is no longer made so there is a chance that if something has to be upgraded, parts might not exist, a complete panel upgrade might be needed. I will need to know that there is room in all the panels for the breaker for the upgrade? Also for the East gate it was said in the addendum that a panel upgrade is needed. For the panel upgrade I need to know how many circuits are needed and what size main breaker is needed to price a panel?

Answer 56

For pricing purposes, assume all Two Jack Main panels have to be replaced with new. Although existing Westinghouse distribution panel at East Gate has capacity to accommodate breaker to power new load, for pricing purposes assume the panel has to be replaced with new. New distribution panel must be able to accommodate all existing loads (shown in photo log) and new loads. Assume new load includes one (1) 1-HP pump requiring one 2-pole 15 A breaker. Assume starter for pump to be wall mounted. Existing panel is a 24 circuit panel. Assume a 100 A main breaker for the panel.

All other Terms and Conditions Remain Unchanged